

$$= 0 \text{ if } t > 4 \times 10^{19}$$

*all values in °F*

### Recent Guidelines

- **USNRC Reg. Guide 1.99 Rev. 2**

$$D = [CF] f(0.28-0.1 \log f) \quad [3-5]$$

where CF is a function of Cu & Ni and a table is given in Reg. Guide 1.99, Rev. 2

- **For the new margin,**


$$d = 28 \text{ for welds}$$

$$d = 17 \text{ for base metals}$$

- **Note correlation with observed and calculated DBTT, (Figure 3-5), (Table 3-3)**

### USNRC Upper Shelf Toughness Requirements

- **10 CFR 50 , Appendix G specifies a minimum upper shelf Charpy impact energy requirement of 68 J (50 ft-lb)**
- **10 CFR 50 also requires that the NRC be notified 3 years in advance of the date when it is estimated that the 68 J limit will be violated**
- **At least 10 US reactors are expected to approach or violate the 68-J limit**



**Figure 3-5.** Plots of observed minus calculated versus calculated values of  $\Delta RT_{NDT}$  for both welds and base metal (Randall 1986). Copyright American Society for Testing and Materials; reprinted with permission.

**Table 3-3.** Comparison of the two methods for calculating the final RT<sub>NDT</sub><sup>a</sup>

Method	Mean shift in RT <sub>NDT</sub> (°F)	Initial RT <sub>NDT</sub> <sup>b</sup> (°F)	Margin (°F)	Final RT <sub>NDT</sub> (°F)
1985 PTS Rule [Equation (3-2)]	177	0	59	236
RG 1.99, Revision 2 and 1991 PTS Rule [Equation (3-5)]	235	0	66	301

a. For an axial, Linde 80 weld with Cu = 0.22% and Ni = 0.77%, and a fluence of  $2.5 \times 10^{19}$  n/cm<sup>2</sup> (E > 1 MeV).

b. Initial value not measured; value assumed following the PTS rule approach.

**before the expiration of their current operating licenses.**

## **Fatigue**

- **Second leading cause of failure in PWR vessels**

*(However, in some US plants with low-radiation-sensitive materials [i.e., Cu < 0.1 wt. % and Ni < 0.6 wt. %] and fluences < 5 x 10<sup>18</sup> n/cm<sup>2</sup>, fatigue could become the leading cause of failure)*

- **Fatigue failure consists of 2 major stages:**

- a.) **Crack initiation**
- b.) **Crack growth**

- **PWR's have advantage over BWR's in crack initiation because of the low O<sub>2</sub> concentration in PWR's.**

- **Crack growth rates:**

**Sub-surface cracks:**  $\frac{da}{dn} = (0.0267 \times 10^{-3}) K^{3.726} \frac{\text{in}}{\text{cycle}}$

**Surface cracks:            large K's**

$$\frac{da}{dn} = (1.01 \times 10^{-1}) (3.75R + 0.06) K^{1.95} \frac{\text{in}}{\text{cycle}}$$

**small K's**

$$\frac{da}{dn} = (1.02 \times 10^{-6}) (26.9R - 5.725) K^{5.95} \frac{\text{in}}{\text{cycle}}$$


where  $R = \frac{K_{\min}}{K_{\max}}$

### Effect of Environment

- See figure 3-6 for the combined effects of mechanical (cycle dependent) and corrosion (time dependent) crack growth.


### Mitigation of Embrittlement Damage

- **Reduction of Thermal Stresses**
  - 1) *Change operating procedures to eliminate off-normal events*
  - 2) *Physically change the plant design*
- **Flux Reductions**
  - 1) *Use low-leakage core loading pattern (25-50% effect)*
  - 2) *Shielding by placing steel rods or dummy fuel elements at outer edge (up to 90% effect)*
- **Thermal Annealing**
  - Wet annealing (with water) at 345 °C has been accomplished in 2 reactors*




9-3149

**Figure 3-6.** The upper bound curve showing total crack growth rate for S533B-1 steel in BWR and PWR coolant (Gilman 1987). Copyright American Society of Mechanical Engineers; reprinted with permission (modified).



**Figure 3-7.** Lateral shift method for estimating reirradiation embrittlement (ASTM 1988c). Copyright American Society for Testing and Materials; reprinted with permission.



**Figure 3-8.** Vertical shift method for estimating reirradiation embrittlement (ASTM 1988c). Copyright American Society for Testing and Materials; reprinted with permission.

***-Dry annealing (in air) @ 430 to 475 °C  
has been accomplished in Russian,  
Finnish, and US reactors***

***-See figure 3-8 for extent of annealing***


- **Surveillance Programs**

- See figure 3-9 for location of  
retrievable specimens***

- See figure 3-10, 3-11 for flux  
profiles***


- Anisotropy of materials properties  
is addressed by taking specimens  
from different rolling directions  
(figure 3-12)***






**Figure 3-9.** Typical locations of surveillance test capsules.


N91 0460



**Figure 3-10.** Typical axial flux distribution (relative to midcore location) at a fixed muthal location.



**Figure 3-11.** Typical azimuthal flux distribution at the core midplane. Azimuthal orientations are shown in Figure 3-9.



S90 0180

**Figure 3-12.** Orientations of Charpy V-notch surveillance specimens taken from vessel base material.


# Boiling Water Pressure Vessels

## *Chapter 18 in Shah*

- **Main Problems:**
  - 1.) **Fatigue**
  - 2.) **Intergranular Stress Corrosion Cracking (IGSCC)**
  - 3.) **Stress Corrosion Cracking (SCC)**
- **See Figure 18-1 and 18-2**
- **BWR Vessels Bigger Than PWR**

*diameters 5.54 to 6.38 m*
- **Early vessels of SA302B**
- **After 1965, used SA533B**
- **See Table 18-1**
- **Neutron exposures lower (see figure 18-8)**
- ***Lifetime exposures  $5 \times 10^{17}$  to  $5 \times 10^{18}$  n/cm<sup>2</sup>***
- **Note effect of recent regulations**

**Figure 18-12**  
**Very little effect  $< 10^{17}$**



N93 0023


**Figure 18-1.** Typical BWR pressure vessel.

**Table 18-1. Examples of BWR pressure vessel steels with their chemical composition.**

Model	Material	Average chemistry (wt%)		
		Cu	P	Ni
BWR/3	Plate	0.17	0.10	0.58
	Weld	0.06	0.01	0.92
BWR/3	Plate	0.10	0.007	0.54
	Weld <sup>a</sup>	0.26	0.013	0.60
	Weld <sup>b</sup>	0.18	0.011	0.20
BWR/4	Plate	0.08	0.01	0.58
	Weld	0.23	0.16	<0.50
BWR/5	Plate	0.06	—	0.63
	Weld	0.07	—	0.71
BWR/6	Plate	0.04	—	0.59
	Weld	0.06	—	1.08


a. Submerged arch weld.

b. Electroslag weld.



**Figure 18-8.** Azimuthal distribution of calculated fast neutron flux at pressure vessel inner wall, and one-fourth and three-fourths thickness (Manahan 1991).





**Figure 18-12.** A comparison of shift predictions for welds and base metal (0.15 wt% Cu, 0.60 wt% Ni and 0.012 wt% P) calculated using Revisions 1 and 2 of Regulatory Guide 1.99.