



Modelling of Lithium-Lead/Water Interactions in a Fusion Reactor Design

J.P. Herzog and M.L. Corradini

**September 1983
(revised August 1984)**

UWFDM-559

***FUSION TECHNOLOGY INSTITUTE
UNIVERSITY OF WISCONSIN
MADISON WISCONSIN***

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Modelling of Lithium-Lead/Water Interactions in a Fusion Reactor Design

J.P. Herzog and M.L. Corradini

Fusion Technology Institute
University of Wisconsin
1500 Engineering Drive
Madison, WI 53706

<http://fti.neep.wisc.edu>

September 1983 (revised August 1984)

UWFDM-559

MODELING OF LITHIUM-LEAD/WATER
INTERACTIONS IN A FUSION REACTOR DESIGN

J.P. Herzog

M.L. Corradini

Fusion Engineering Program
Nuclear Engineering Department
University of Wisconsin-Madison
Madison, Wisconsin 53706

September 1983

(Revised August 1984)

UWFD-559

Prepared for EG&G Idaho Inc. and the Department of Energy Idaho Operations
Office under DOE Contract No. DE-AC07-76ID01570.

MODELING OF LITHIUM-LEAD/WATER INTERACTIONS IN A FUSION REACTOR DESIGN

J.P. Herzog and M.L. Corradini

University of Wisconsin, Madison, WI 53706

Abstract

A parametric model was developed to predict the transient pressure and temperature behavior for a liquid-metal/water interaction in a steam generator following an assumed tube rupture. The model results suggest two preliminary conclusions. First, the maximum temperature for lithium-lead due to the reaction, although above normal limits, is below the thermodynamic maximum value rapidly falling to within operating limits. Second, the pressure history and hydrogen generated from water injection into lithium or lithium-lead are quite similar for a given value of the metal/water mixing parameter. This suggests that the pressure-flow characteristics govern the integral response given an assumed degree of chemical reaction. For a more accurate prediction of the accident response one must consider the reaction kinetics for lithium and lithium-lead interactions; e.g. lithium may be a "vapor phase combustion" process while lithium-lead would be governed by metal surface mass transfer phenomena. Under the contact mode considered complete reduction of water to hydrogen cannot be precluded.

Introduction

Lithium and its alloys, in particular lithium-lead alloys, have been considered recently as possible breeder-blanket materials in conceptual designs of fusion power reactors, due to their favorable neutronic, breeding, and heat transfer properties. These materials do represent some safety hazard, though, due to their chemically reactive nature with other reactor materials, e.g. air, water, and concrete.

Current evaluations of the hazard potential of lithium and lithium-alloy breeders in contact with other reactor materials has been based upon thermodynamic calculations of possible chemical reactions, and on dynamic parametric calculations for specific fusion reactor designs. These calculations have led to rough comparisons of the overall hazard potential of different lithium and lithium-alloy breeders with other potential reactor materials.^(1,2) Also, scoping experiments were performed at Argonne National Laboratory by R. Clemmer et al.⁽³⁻⁵⁾ and are now underway at HEDL by L. Muhlestein.⁽⁶⁾ These tests indicated that qualitatively the reaction between lithium and lithium-alloy breeders with H_2O is quite different (see Table 1). Additional work by Jepson et al.⁽⁷⁾ with lithium-alloys and the ternary oxides ($LiAlO_2$, $LiSiO_3$, Li_4SiO_4 , and $LiTiO_3$) showed that these oxides present minimal safety related problems when used with H_2O ; however, they do require neutron multipliers, such as lithium-lead for breeding and power needs. They go on to state that "...the combined favorable neutronics and minor safety compatibility concerns of lithium oxide and $Li_{17}Pb_{83}$ (a particular eutectic lithium-lead alloy; Li 17 a/o) make them prime candidates as blanket materials." Recently some European investigators^(8,9) have initiated studies on the potential of certain breeder-

Table 1. Reactions of Li-Pb Alloys and Lithium With Water

<u>Case</u>	<u>Composition</u>	<u>Sample</u>		<u>Water</u>	
		<u>State^a</u>	<u>Temp/°K</u>	<u>Temp/°K</u>	<u>Reaction</u>
1	Li ₇ Pb ₂	s	773	298	Modest
2	Li ₇ Pb ₂	s	773	369	Vigorous
3	Li ₇ Pb ₂	s	873	368	Vigorous
4	Li ₇ Pb ₂	ℓ	1103	368	Very Vigorous
5	Li _{0.62} Pb _{0.38}	ℓ	773	368	Vigorous
6	Li _{0.17} Pb _{0.83}	ℓ	773	368	Very Modest
7	Li	ℓ	773	368	H ₂ Detonation
8	Li ^b	ℓ	773	368	Detonation

^a s = solid, ℓ = liquid

^b injected under water


blanket designs and have provided specific design proposals to reduce the overall hazard potential of a $\text{Li}_{17}\text{Pb}_{83}$ breeder-blanket.

Our current work is being done in conjunction with the DOE Fusion Safety Program and previously with the Mirror Advanced Reactor Study (MARS).⁽¹⁰⁾ The MARS conceptual fusion reactor design utilizes the lithium-lead alloy $\text{Li}_{17}\text{Pb}_{83}$ (hereon designated as "lithium-lead") as a liquid-metal breeder and primary coolant. Based upon a number of previously mentioned reasons,⁽³⁻⁷⁾ "lithium-lead" was chosen as the breeder-coolant for the MARS design; e.g. high tritium breeding ratio, good neutron multiplication, acceptable corrosion rates, and relatively benign chemical reaction rates with water and air.

We limit our comments to the lithium-lead/water and the lithium/water interactions as applied to a MARS conceptual fusion reactor design. For various accident sequences one can identify four possible "contact modes" between the molten metal breeder and the water. These "contact modes" are important because they determine how the molten metal and water will hydrodynamically mix and the energy and mass transfer rates between the materials. The first contact mode might occur after a tube rupture in a liquid-metal steam generator. One could identify this contact mode as "coolant injection" due to the high pressure injection of the steam/water into the low pressure liquid-metal (Fig. 1). The second contact mode would be characterized by pouring of the liquid-metal from a ruptured blanket component into a pool of water, also present due to the accident. This contact mode is identified as a "pouring contact mode." A "Melt-Coolant" interaction is a generic class of heat transfer phenomena in which one hot liquid, "melt," interacts with a more volatile cold liquid, "coolant," producing vapor and perhaps oxidizing the melt. Historically, this contact mode has been considered in fission reactor safety,

Fig. 1

STEAM GENERATOR TUBE RUPTURE



- HIGH PRESSURE TWO-PHASE BLOWDOWN

- LIQUID METAL ENTRAINED IN EXPANDING MIXING ZONE

although the other modes of contact are just as plausible. This contact may occur, in a fusion reactor, after a severe accident in which molten metal is poured from a ruptured component into a stagnant pool of water in the containment (Fig. 2). The third contact mode could be characterized by a rupture of water and breeder-blanket tubes in the vacuum vessel (i.e. torus or central cell), resulting in a spray of these reactants into a common volume (Fig. 3). This contact mode is of special concern in a fusion design because the major radioactive inventory resides within the vacuum vessel. One may consider this contact mode to be a subset of the previous two, because it is the simultaneous injection of the liquid-metal breeder and water into a common volume. The fourth contact mode would occur if the liquid-metal and the water came into contact as stratified layers of materials with different densities (e.g. lithium pouring on water, water pouring on lithium-lead). We expect this to be the most benign of the possible contact modes because even though the two materials are liquid, density stratification would initially limit their surface area for mixing.


This paper will be concerned only with modeling the first contact mode, coolant injection. A model for the second, metal pouring, has been presented elsewhere.⁽¹¹⁾ This mode was originally developed for fission reactor safety concerns,^(12,13) and can be easily modified for a fusion reactor case. We plan to investigate the third and fourth contact modes in future work.

Background

For the coolant injection we specifically consider a steam tube rupture accident in a Westinghouse liquid-metal/water steam generator,⁽¹⁴⁾ the specifications of which are given in Fig. 4. The model being developed predicts the temperature and pressure history and the hydrogen generation rate due to

Fig. 2


LIQUID METAL SPILL IN CONTAINMENT



LIQUID-METAL / CONCRETE INTERACTIONS

Fig. 3


COOLANT LEAKAGE INTO VACUUM CHAMBER



- SIMULTANEOUS LEAKAGE OF TWO FLUIDS DUE TO A COMMON FAULT (e.g. SEISMIC EVENT)
- MIXING OF FLUIDS IS HIGHLY SITUATION DEPENDENT AND PROBABLY VERY LIMITED
- THIS CONTACT MODE CAN BE EXCLUDED FROM FURTHER CONSIDERATION

Fig. 4

WESTINGHOUSE STEAM GENERATOR



an assumed guillotine break of a steam tube and the resulting liquid-metal/water chemical reaction. The model is applied to both a lithium and lithium-lead breeder in order to obtain a general comparison between these two candidate breeder-blanket materials. We also present a reliability and availability analysis for the steam generator in Appendix A.

In 1981, Krane and Kazimi⁽¹⁾ compared lithium and lithium alloy/water reactions for a hypothetical coolant tube leak in the blanket of the University of Wisconsin NUWMAK conceptual fusion reactor. They first performed a thermodynamic calculation where the breeder and coolant were allowed to interact instantaneously and then determined the final equilibrium temperature of the blanket materials, based on a stoichiometric amount of water and breeder, with a variable degree of completion of the chemical reaction (0 to 100%). Next, a dynamic calculation was performed in which the LITFIRE computer program⁽¹⁾ was modified to predict the thermal response of the blanket materials. The calculation was based on a specified flow rate of water (0.2 kg/s) into a constant volume, spherically shaped reaction zone, in which the reaction occurred and the reaction products remained. They determined the temperature response of concentric shells of the undisturbed breeder material and used the resulting temperature profiles as the basis for their qualitative comparison of the hazard potential of different lithium-alloy based breeders. The analysis did not vary the leakage rate of coolant into the breeder and neglected the pressure transient within the breeder zone. This analysis was therefore most applicable for very slow leaks over the long time spans.

Our current investigation extends this preliminary work. We begin with a thermodynamic equilibrium calculation to determine the final temperature of a mixture of lithium, lithium-lead and water. We generalize this calculation so


that it only depends upon the initial molar ratio of water to lithium in the mixture and not on any absolute amount of water or liquid-metal. A dynamic calculation is then performed using a parametric model to predict the consequences of a steam tube rupture. Our parametric model allows for a number of effects:

- 1) a dynamic reaction zone volume,
- 2) variable liquid-metal/water mixture ratios,
- 3) a dynamic pressure calculation,
- 4) pressure relief valve flow out of the steam generator,
- 4) a critical flow model for the tube rupture break flow.


In the next section, we discuss the thermodynamic equilibrium model followed by a discussion of the model and the current results. Finally, some current thoughts on the mechanism for liquid-metal/water chemical reactions are presented.

Thermodynamic Equilibrium Model

The stoichiometric chemical reaction for lithium with water is



and for lithium-lead with water



where i_f is the heat of formation of $\text{Li}_{17}\text{Pb}_{83}$ (see nomenclature). The thermo-

dynamic equilibrium modeling determined, for various amounts of liquid-metal and water, the final equilibrium temperature of the products and any remaining reactants; assuming that the energy generated by the reaction does not leave the "fuel-coolant" system. The initial temperature of the reactants is given by the average temperature of the metal breeder and water in the steam generator (for the MARS fusion design, 400°C for the metal at 1.7 bars and 375°C for the water at 170 bars). To determine the final equilibrium temperature of the system, we simply balance the energy of the reactants and the products of the above reactions, for a given ratio of initial moles of lithium to moles of water (defined as the parameter $x \equiv n_{H_2O}/n_{Li}$). Given x , one can solve for the final equilibrium temperature regardless of the absolute amount of reactants. The energy balance has three forms depending on whether $x < 1$, $x = 1$, or $x > 1$. For the lithium breeder the three balances are

$$C_L[T_{B0} - T_0] + xi_{w0} = [C_{LH} + C_H][T_f - T_0] + Q + [x - 1]i_{wf} \quad \text{for } x > 1 \quad (3a)$$

$$C_L[T_{B0} - T_0] + i_{w0} = [C_{LH} + C_H][T_f - T_0] + Q \quad \text{for } x = 1 \quad (3b)$$

$$C_L[T_{B0} - T_0] + xi_{w0} = x[C_{LH} + C_H][T_f - T_0] + xQ + [1 - x]C_L[T_f - T_0] \quad \text{for } x < 1 \quad (3c)$$

The equations for lithium-lead are similar in form to these.

The results of this calculation are shown in Figs. 5 and 6, for the final equilibrium temperature (T_f) as a function of the parameter x for lithium and lithium-lead.

FIGURE 5

THERMODYNAMIC EQUILIBRIUM TEMPERATURE (T_f) vs. X FOR Li BREEDER





FIGURE 6

THERMODYNAMIC EQUILIBRIUM TEMPERATURE (T_f) vs. X FOR $Pb_{83}Li_{17}$ BREEDER



In Fig. 5 the constant equilibrium temperature indicates 1.7 bars where lithium and lithium hydroxide begin to vaporize (25 psia). This calculation would produce higher equilibrium temperatures as the pressure in the vicinity of the interaction increases; e.g. for a high pressure of 170 bars the peak equilibrium temperature would be 3800°C. The $\text{Li}_{17}\text{Pb}_{83}$ energy balance was carried out for two values of the heat of reaction (Q). One of the values of Q (-8.33 kcal/(gmole of $\text{Li}_{17}\text{Pb}_{83}$)) is arrived at by assuming that the heat of formation of $\text{Li}_{17}\text{Pb}_{83}$ (i_f) is negligible. The other value of Q (-6.36 kcal/(gmole of $\text{Li}_{17}\text{Pb}_{83}$)) is arrived at by including an estimate of the heat of formation, i_f . This estimate of the heat of formation of $\text{Li}_{17}\text{Pb}_{83}$ is given by

$$i_f = \Delta G + T\Delta S \quad (4)$$

where G is the Gibbs free energy and S is the entropy as calculated by E.M. Larsen.⁽¹⁵⁾

This thermodynamic calculation provides an upper bound on the mixture in the reaction zone of the steam generator, due to a steam tube rupture. Comparison of Figs. 5 and 6 shows that the lithium-lead may produce substantially lower temperatures than lithium, primarily due to the much larger thermal inertia of the lead. Also, the liquid lithium may produce substantial system pressure increases due to vaporization of the lithium or lithium-hydroxide for a constant volume situation. The possible vaporization of Li or LiOH from using a pure lithium breeder would pose additional safety hazards as lithium and associated radioactivity may take the form of mobile aerosols.

Dynamic Parametric Model

The model for the coolant injection contact mode is applied to a Westinghouse liquid-metal steam generator.⁽¹⁴⁾ This design is the most logical choice, since Westinghouse is currently involved in the component development of a large prototype steam generator for LMFBR applications and fusion systems.

The Westinghouse "duplex tube" design (Fig. 4) utilizes double walled tubes with a helium gas at the interface of the two tubes, that can be used for detection of small leaks in either tube. The MARS design requires that 2840 MW of energy from the blanket be transferred across the steam generator with a temperature drop of 350° to 300°C. Since the design power rating of the Westinghouse steam generator is 293 MW, the MARS power station would require ten steam generators of this design. The large number of plant steam generators, although more expensive than a smaller number, would reduce the hazard of steam generator accidents, by confining the accident to a single generator and isolating the extent of damage and cleanup or replacement costs.

The steam generator accident modeled is one in which there is a sudden and complete rupture of a steam tube ("guillotine break"), essentially leaving two water flow paths into the liquid-metal. Since the water is at a much higher pressure than the metal breeder (170 versus 1.7 bars), the mode of contact between the liquid-metal breeder and the water is high pressure coolant injection. For our current calculations, our model contains these major assumptions:

- 1) We base our calculations on the MARS design parameters. The initial pressure of the reactants is 17. MPa for the water and 0.17 MPa for the

breeder. Also, the initial shell side, liquid-metal breeder volume and temperature are taken to be $2.78 \times 10^7 \text{ cm}^3$ and 673 K, respectively.

- 2) There are two interaction zones. The first zone, designated the Reaction Zone, is assumed to be a spherically shaped region that forms around the break. This zone is a homogeneous mixture of reactants and products at thermal equilibrium, which can grow in time. The other zone, designated the Nonreaction Zone, consists of the rest of the shell side of the steam generator. This zone is assumed to be a homogeneous region of unreacted liquid-metal breeder at thermal equilibrium.
- 3) The flow rate of water into the reaction zone is modeled by the one-dimensional homogeneous equilibrium model (HEM) for critical flow, i.e.

$$S_{wo} = S_{wb} \quad (5)$$

$$V_{wb} = [2(i_{wo} - i_{wb})]^{1/2} \quad (6)$$

$$\dot{m}_w = A_b \rho_{wb} V_{wb} \quad (7)$$

where the enthalpy at the break location, i_{wb} , is found knowing S_{wb} and P_{wb} .

- 4) The flow of the liquid-metal breeder into the reaction zone is determined by a mixing parameter x . x is defined as the ratio of the molar flow rate of water to the molar flow rate of lithium into the reaction zone.
- 5) The reactants, including hydrogen, remain in the reaction zone.
- 6) The system pressure is maintained below 170 bars (the water back pressure) by a pressure relief valve. This is accomplished by allowing a portion of

the unreacted liquid-metal breeder to leave the nonreaction zone each timestep through the valve. The flow rate out through the valve is modeled by a quasi-steady mechanical energy balance (Bernoulli's equation)

$$\dot{m}_{bp} = \rho_b A_{prv} \left[\frac{2}{K\rho_b} (P - P_\infty) \right]^{1/2} \quad (8)$$

where K is the loss coefficient through the valve (isentropic would be K = 1).

- 7) We assume that the increase in pressure in the shell side of the steam generator suspends the normal flow of the metal through the steam generators.
- 8) There is no back flow through the broken steam tubes.
- 9) The thermodynamic and transport properties of the liquid-metal reactants and products are assumed to be simple functions of temperature. The liquids are incompressible. The gases are perfect. For $x > 1$, any unreacted water is assumed to be superheated steam.

This parametric model is the next logical step beyond a simple thermodynamic calculation. We employ two control volumes and a specified mixing parameter in order to keep the modeling of the dynamic process relatively simple and unambiguous; this seems justified because our current knowledge of the mechanisms of liquid-metal/water interactions is so limited. Consistent with this approach is the use of a 1-D HEM critical flow model for water inflow and a quasi-steady mechanical energy balance for liquid-metal outflow. Because the pressure transient within the shell side of the steam generator is expected to be large but less than the 170 bar in the water, assumptions 7 and 8 are quite reasonable. Because the transient caused by the tube rupture occurs over such

short times (1 s) the retention of H_2 in the reaction zone is reasonable (assumption 5). Finally, the simple equations of state for liquid-metal and water are known to be approximate; subsequent calculations will investigate the effect of using more complete equations of state.

Using the mixing parameter, x , and the relief valve area, A_{prv} , as variables and the above assumptions, we solve the following mass and energy balances:

Reaction zone mass balance

$$\frac{dm_R}{dt} = \dot{m}_{br} + \dot{m}_w . \quad (9)$$

Reaction zone energy balance

$$\frac{dE_R}{dt} = -Q_c - Q_r - p \frac{dV_r}{dt} + \dot{m}_{br} i_b + \dot{m}_w i_w \quad (10)$$

where the reaction zone forced convection heat transfer (Q_r) to the unbroken coolant tubes is given by

$$Q_r = h_t A_{t_r}(t) (T_r - T_w) . \quad (11)$$

The convective heat transfer coefficient, h_t , is calculated based on the shell and tube side flow and the heat transfer resistance across the steel tubes; the steel tube dominates the heat transfer resistance. The conductive heat transfer between the reaction zone and the nonreaction zone (Q_c) is given by

$$Q_c = 4\pi R^2 \frac{kn}{\lambda} (T_r - T_n) . \quad (12)$$

The penetration depth, λ , is the conduction length scale from boundary layer theory. The area, $4\pi R^2$, is based on the assumption of a spherical reaction zone.

The nonreaction zone mass balance is

$$\frac{dm_n}{dt} = -\dot{m}_{br} - \dot{m}_{bp} , \quad (13)$$

and the nonreaction zone energy balance is

$$\frac{dE_n}{dt} = Q_c - Q_n - p \frac{dV_n}{dt} - \dot{m}_{br} i_b - \dot{m}_{bp} i_b \quad (14)$$

where the nonreaction zone forced convection heat transfer, Q_n , to the unbroken coolant tubes is given by

$$Q_n = h_t A_{t_n}(t)(T_n - T_w) . \quad (15)$$

The areas A_{t_r} and A_{t_n} in Eqs. (11) and (15) sum up to the total tube surface area. One should note that the energy balances include the heat of formation of each constituent and therefore automatically include the heat of reaction from the oxidation of lithium.

Approximating the differentials by finite difference techniques, we have written a computer program that explicitly calculates shell side pressure, reaction and nonreaction zone temperature, and the hydrogen mass generated, all as functions of time from the accident initiation. For information concerning the use and structure of the computer program, the reader is referred to Appendix B.

In Fig. 7, we have plotted the system pressure as a function of time for three different values of the pressure relief valve area, A_{prv} . This parameter is used to determine the flow rate of unreacted liquid-metal breeder out of the system by Eq. (8). A comparatively small value of A_{prv} would mean a comparatively small flow rate of unreacted liquid-metal breeder out of the system, and little pressure relief. This is illustrated in Fig. 7 by comparing the top curve ($A_{prv} = 0.005 \text{ m}^2$) with the other two curves ($A_{prv} = 0.01 \text{ m}^2$ and $A_{prv} = 0.05 \text{ m}^2$). One notes that the system pressure quickly approaches the limiting pressure of the high pressure water (17 MPa), for smaller values of A_{prv} . Another trend illustrated in this, and which is exhibited in the results of every calculation, is that the system pressure quickly ($< 1 \times 10^{-4} \text{ s}$) reaches a maximum pressure (P_{max}), and levels off near P_{max} for the early part of the calculation. In Fig. 8, we have plotted the maximum system pressure as a function of A_{prv} for both lithium and lithium-lead liquid-metal breeders. The similar shape of the two curves in this figure indicates a relationship between the lithium and lithium-lead. From Eq. (8), the flow rate of unreacted liquid-metal breeder out of the system (\dot{m}_{bp}) is proportional to A_{prv} and the square root of the liquid-metal breeder density (ρ_b)

$$\dot{m} \propto A_{prv} (\rho_b)^{1/2} . \quad (16)$$

If the abscissa of Fig. 8 was $\rho_b^{(-1/2)} A_{prv}$ instead of A_{prv} , the two curves would be coincident. This similarity in behavior for the two liquid-metal breeders is demonstrated in Fig. 9.

The liquid-metal/water interaction with a fixed value of x is governed by the pressure response. This is because the flow rate of water into the re-




Figure 7




Figure 8




Figure 9

action zone (and thus the flow rate of liquid-metal breeder through x) is a function of the system pressure. The flow rate of unreacted liquid-metal out of the system is also a function of the system pressure. Thus, the flow rates into and out of the system are coupled together through the pressure history. For a constant mixing parameter (e.g., $x = 1$) the integral pressure behavior and hydrogen generated into lithium or lithium-lead is very similar. If we attempt to determine the mechanistic amount of hydrogen generated this preliminary conclusion might be altered. However, at this point in our modeling of the melt-water interaction we do not feel there would be a large difference in the amount of lithium reacted with water for Li or LiPb. The reason is that the water is injected into an almost infinite sea of liquid metal and probably has enough time to completely chemically react. A variance in the mixing parameter to more realistic values may alter the peak temperatures and pressures calculated in the reaction zone, but not the degree of chemical reaction; i.e. all the water is reduced to hydrogen.

One would not expect the temperature response of the two liquid-metal/water pairs to be similar because of the lower thermal inertia of lithium.

In Fig. 10, we have plotted the temperature of the reaction zone (T_r) and the temperature of the nonreaction zone (T_n) as functions of time, for a typical calculation. This figure illustrates representative trends in the two temperatures, regardless of the values of the parameters X and A_{prv} or the choice of the liquid-metal breeder. The trend in the reaction zone temperature is that it reaches its maximum temperature ($T_{r_{max}}$) very early in the calculation, and then steadily decreases to an asymptotic temperature (648 K). The trend in the nonreaction zone temperature is that it steadily decreases from its initial temperature (673 K) to an asymptotic temperature (648 K). This




Figure 10

asymptotic temperature is the ambient temperature of the water in the unbroken steam temperature. This shows that the energy from the exothermic reaction is quickly and effectively removed from the system by forced convection through the unbroken steam tubes. This occurs because the accident suspends the normal flow of liquid-metal breeder through the steam generator due to the rapid pressure buildup. The normal function of the steam generator, which is the transfer of the energy of the liquid-metal breeder, is thus diverted to transfer of the chemical heat of the reaction. The reason that the maximum reaction zone temperature is reached early is because the amount of the reaction products in the reaction zone is at a minimum. Therefore, the amount of heat absorbed by the reaction products is also at a minimum.

Figure 11 presents the temperature history of the reaction zone, T_r , for lithium and lithium-lead liquid-metal breeders, for the same values of X and A_{prv} . The peak lithium temperature is significantly higher than the peak lithium-lead temperature. The major reason is again the large thermal storage capacity of lithium-lead compared to lithium. This peak temperature for lithium is above the melting point of the stainless steel (~ 1800 K). When the reaction zone temperature decreases to 1800 K (in roughly 10 ms), the reaction zone volume is approximately 0.01 m^3 . Assuming a spherical reaction zone, this corresponds to a reaction zone radius of 0.13 m. Because the steam tube pitch is 0.037 m, the high reaction zone temperature may cause failure of surrounding tubes causing the tube rupture to propagate to surrounding steam tubes. This would not be the case for lithium-lead, because the reaction zone temperature is far below the steel melting point.

In Fig. 12, we have plotted the maximum reaction zone temperature as a function of the mixing parameter x , for lithium-lead. Comparing Fig. 12 to




Figure 11




Figure 12

Fig. 6 ($Q_R = -6.36 \text{ kcal/(gmole of Li}_{17}\text{Pb}_{83})$), one sees that both the parametric model and thermodynamic equilibrium model exhibit the same variation in temperature as a function of x . The main difference, as exhibited in these two figures, is that the parametric model predicts lower temperatures than the thermodynamic equilibrium model. The reason for this is that the parametric model allows energy to flow out of the system through the pressure relief valve and through convection to unbroken steam tubes, while the thermodynamic equilibrium model has no provision for energy transfer from the system. The reason that the curves in Fig. 12 and Fig. 6 exhibit the same temperature response as x varies, is that because if x is greater than 1, some of the water entering the reaction zone does not react but absorbs energy from the reaction; and likewise, if x is less than 1, some of the lithium or lithium-lead entering the reaction zone does not react but absorbs energy from the reaction.

Considerations for Liquid-Metal/Water Reactions

Given a mixing ratio between the liquid metal (Li or $\text{Li}_{17}\text{Pb}_{83}$) and water, the parametric model indicated that the pressure history and hydrogen generated are quite similar. The temperature history of each is different, although both are below the thermodynamic limits. The next step in our work is to relax the assumption of a constant mixing parameter ratio, X , and investigate the fundamental rate mechanisms for liquid metal oxidation. In this way we can improve our chemical reaction modeling and more accurately determine if the amount of hydrogen generated is different for different lithium alloys under different contact modes. This may be an important consideration in determining the hydrogen inventory after an accident.

The amount of hydrogen generated during a liquid-metal/water interaction is the product of two physical processes; the first is the kinetic rate of reaction per unit surface area, and the second is the available metal surface area that evolves during the "fuel-coolant" interaction. Metal oxidation is practically limited by mass transfer in the gas and liquid (or solid oxide) phases near the metal surface.^(17,18) In the gas phase, steam must diffuse through the evolved hydrogen to the liquid metal surface. If the chemical reaction is exothermic and the heat of reaction is large, the liquid metal surface will heat up substantially as it oxidizes until the liquid metal vapor pressure becomes significant causing substantial liquid metal vapor evaporation, oxidizing as it diffuses into the steam vapor. This vapor-phase oxidation of the liquid metal is the dominant mechanism of normal combustion processes; it has a very rapid oxidation rate. Liquid sodium oxidation is thought to be governed by this mechanism.⁽¹⁹⁾

Because of the low thermal inertia of lithium, it is quite possible that under certain circumstances lithium metal can overheat sufficiently and undergo "vapor-phase combustion."⁽¹⁹⁾

On the other hand, if the liquid metal vapor pressure is negligible at comparable temperatures as in the case of lithium-lead (the lithium chemical activity is 0.1% that in pure lithium), then steam vapor must diffuse to the metal surface through evolved hydrogen for liquid metal oxidation. Following past work,⁽¹⁷⁾ the governing mass transfer equation for this process can be written in a general form for equimolar counterdiffusion of perfect gases (steam and hydrogen) as

$$\frac{dN_H}{dt} = A \frac{D_H}{R_0 T_V} \frac{dP_H}{dn} \quad (15)$$

where: dN_H/dt is the molar rate of hydrogen diffusion in steam (mole/s)

D_H is the diffusion coefficient for steam and hydrogen

R_0 is the universal gas constant

P_H is the hydrogen partial pressure

T_V is the gas-vapor temperature

n is the outward directed normal

A is the surface area.

One can integrate this equation for a certain geometry, assuming a constant D_H for a pressure and a mean gas temperature.

The second mass transfer resistance, in the absence of "vapor-phase combustion," is the diffusion of oxygen atoms through the metal oxide (liquid or solid) to the unreacted metal. This diffusional process is quite complex; for example, for solid oxide being formed on the metal surface, the hydrogen generation rates are usually correlated from test data⁽¹⁸⁾ under the boundary conditions that an excess of steam is present and the solid metal oxide resists further mass transfer. For zirconium,⁽¹⁸⁾ the rate of reaction is given by a parabolic kinetic rate expression

$$\frac{d}{dt} (W^2) = 3.8(10^3) \exp\left(\frac{-84300}{R_0 T_V}\right) \quad (16)$$

where W is the cumulative mass of hydrogen in kg/m^2 and R_0 is given here in $\text{cal/gmole } ^\circ\text{K}$. Now for a liquid oxide the process is even more complex because the oxide may be miscible in the metal or the molten metal and oxide components could become mechanically mixed by internal convection currents. In this case, very little data exists for liquid metals.

At the present time there have been no controlled experiments that measure the kinetic rate of reaction for lithium or lithium based alloys' oxidation. Therefore, it is not yet clear what the reason is for the qualitatively less reactive behavior observed for lithium-lead as compared to lithium in scoping tests.⁽³⁻⁵⁾ Our intention is to perform simple experiments to determine the rate of chemical reaction for these liquid metals.

The second physical process to consider is the available surface area for reaction that is evolved during liquid-metal/water contact. For this coolant injection mode of contact the water is depressurized as it flows out the break and begins to flash into steam as it reacts with the liquid metal. In the current model we consider the reaction zone to be spherical and to remain intact during the reaction. In reality though the water-steam mixture will break apart into individual bubbles and rise in the liquid metal. The available surface area then will be dictated by the breakup of the two-phase jet issuing forth from the break, and the rise time of the steam and water to the liquid metal surface at the top of the steam generator. In the current contact mode with a "large" inventory of liquid metal we would expect complete chemical reaction to be quite possible. We are now considering the modeling of the jet breakup and bubble transport to determine the limits of complete chemical reaction.

Conclusions

A parametric model was developed to predict the transient pressure and temperature behavior for a liquid-metal/water interaction in a steam generator following a steam tube rupture. The model results suggest two preliminary conclusions. First, the maximum temperature for lithium-lead during the reaction is not a safety concern for the steam generator, because it is below

the thermodynamic maximum value and the melting point of the steel tube and quickly falls to within operating limits. Second, the pressure history and hydrogen generated from water injection into lithium or lithium-lead are quite similar for a given value of the metal/water mixing parameter. This suggests that the pressure-flow characteristics govern the integral response given an assumed degree of chemical reaction. For a more accurate analysis, one must consider reaction kinetics for lithium and lithium-lead interactions; it is expected that lithium may be a "vapor phase combustion" process while lithium-lead is governed by metal surface mass transfer phenomena.

Acknowledgement

Support for this work has been provided by the U.S. Department of Energy through the EG&G Fusion Safety Program. Special thanks are extended to S. Piet for helpful suggestions and encouragement.

APPENDIX A

AVAILABILITY/RELIABILITY ASSESSMENT OF A LIQUID METAL STEAM GENERATOR

An important part of the design of any large component of a nuclear power plant system is the evaluation of the qualitative and quantitative reliability and availability of that component. The reliability of the component is expressed by the probability that it will perform properly under stated conditions for a stated time. The availability of the component is defined as the fraction of time the system is operational.

The assessment of the reliability and availability of a component generally encompasses three procedures. First a qualitative analysis is performed that provides the designer with an identification of the various failure modes that contribute to the system unreliability. Next, a quantitative analysis is performed which provides the designer with a numerical value for the reliability and availability of the component. The final step is to provide an extensive test on parts of the component, or a scaled down version of the component to verify the qualitative and quantitative analysis.⁽²¹⁾

Besides conducting an extensive project into the design and development of a liquid metal steam generator, Westinghouse conducted a qualitative and quantitative analysis of the reliability and availability of a number of liquid metal steam generator designs.⁽¹⁴⁾ Given the present limited operating experience with liquid metal heat exchangers, available data from PWR steam generators and engineering judgement have been used liberally in the quantitative analysis. Therefore, the reliability and availability estimates predicted by the quantitative analysis are most useful in comparing the relative merit of alternative designs. We have used the Westinghouse quantitative

analysis to evaluate the relative merit of the duplex tube with leak detection design and the single tube design, with both designs satisfying the MARS heat transfer requirements. Although the Westinghouse analysis is applied to a liquid sodium steam generator, we assume the analysis can be applied to a liquid lithium-lead steam generator, because of the similarity in physical and transport properties between liquid sodium and liquid lithium-lead alloys.

The Westinghouse qualitative analysis was based on limited failure data from the operation of liquid sodium heat exchangers.

The analysis leads to the following conclusions. Because two-thirds of the failures are located at welds, associated with welded joints, or are suspected of occurring in weld areas, these weld areas require special design quality assurance and development attention. Corrosion related failures are also prominent. Another important observation is that no failure has occurred while operating at rated power. Leaks are most likely to occur during start-up, shutdown, or power level changes.

The quantitative analysis conducted by Westinghouse was begun by constructing a fault tree based on observations from the qualitative analysis. The fault tree analysis begins by selecting the top failure event and then determining the probability of this event occurring. In this analysis, the top failure event is the forced shutdown of the steam generator. Based on the probability of subordinate events occurring, the probability of the top failure event occurring can then be determined. This analysis can be cast into algebraic equations, with the probability of subordinate events and the number of tubes in the steam generator as independent variables.

For the duplex tube design with leak detection, the analysis identified three scenarios that lead to the shutdown of the steam generator. The first

scenario identified is the detection of a water leak but no reaction. This would mean that either the tube has failed but the other tube still holds. The second scenario identified is characterized by a small leak with a relatively small, localized reaction. The third scenario is characterized by a large leak with a large reaction; this is the type of accident scenario on which the models in the paper are based. For the single tube design, the first accident scenario, as described above, could not occur, since any tube failure would lead to the water and liquid metal coming into contact.

The weakness of the Westinghouse analysis is that they have very little data on which to base the probabilities of the subordinate events occurring. For the duplex tube design, the subordinate events can be broken down into four event groups. The first event group consists of the failure of the inner tube. Westinghouse assumes that the probability that the inner tube will fail is equal to the probability that a steam tube, of equal thickness, will fail in a PWR steam generator:

$$\lambda_i = \lambda_{\text{PWR}} . \quad (\text{A.1})$$

This is a conservative probability, since in the PWR, the tube contacts relatively caustic water on both sides of the tube; while in the duplex tube design, the tube contacts water on the inside and relatively inert helium on the outside. The second group consists of the failure of the outer tube. One would expect that the probability that the outer tube fails would be less than the probability that the inner tube fails, because the outer tube contacts the liquid-metal, which is less caustic than water, on the outside and relatively inert helium on the inside. Westinghouse assumes that the probability that

the outer tube fails is equal to the probability that the inner tube fails multiplied by a factor (C_1), which is less than 1:

$$\lambda_o = C_1 \lambda_i . \quad (A.2)$$

For their analysis, Westinghouse assumes C_1 equals 1/10. The third group consists of interdependent failures. An interdependent failure occurs when one tube fails due to the failure of the other tube. Given the failure of the outer tube, the probability that the inner tube will fail will be small because the liquid-metal must migrate across the helium gap, and the helium is at a higher pressure than the liquid-metal. In the Westinghouse analysis, the probability that the inner tube will fail, given the failure of the outer tube, is determined by a factor (C_2) that equals 1/20. Given a failure of the inner tube, the probability that the outer tube fails will be larger than the other interdependent failure because of the higher pressure and the more caustic nature of the water. Again, the probability that the outer tube fails, given the failure of the inner tube, is determined by a factor (C_3) that equals 3/4. The fourth event group consists of the probability that an originally small break will deteriorate into a large break, leading to the accident scenario, on which the bulk of this paper is based. In the Westinghouse analysis, the probability of a large break occurring, given a small break, is determined by a factor (C_4), which arbitrarily equals 1/10. This means that 1 in every 10 small breaks will deteriorate into a large break.

For the single tube design, of the four factors described above, only the fourth (C₄) comes into play. Also, the probability that the steam tube will fail is equal to the probability that a PWR steam tube will fail.

With the equations based on the fault tree analysis, and with the probabilities and factors described above, the overall probability that a forced shutdown of the steam generator will occur (λ_{SG}) can be approximated. This probability is a measure of the unreliability of the steam generator. A more significant measure of the relative merit of a design is the unavailability of the component. It is a measure of the fraction of operating time that the component can be expected not to be operating due to an accident, which causes the forced shutdown of the component, and the time it takes to repair the component. The unavailability can be expressed as

$$E_U = \frac{\lambda}{\mu + \lambda} \quad (A.3)$$

where μ is the reciprocal of the time needed to repair the component after an accident, and λ is the probability that the accident occurs. For each of the three accident scenarios described earlier in this section, Westinghouse has determined the probable amount of time needed to repair the steam generator. For the detected leak but no reaction scenario, the repair time is 10 days. For the small leak and localized reaction scenario, the repair time is 7 weeks. For the large leak and extensive reaction scenario, the repair time is 13 months.

In our analysis, we have taken the Westinghouse equations based on their fault tree analysis and applied them to the duplex tube with leak detection and the single tube steam generator designs. Both designs fulfill the MARS

heat transfer requirements. For the duplex tube design, this translates into a steam generator with 3286 duplex tubes. For the single tube design, if we assume the thickness of the single tube is equal to the total thickness of the duplex tube, the steam generator would require 2450 single tubes. Even though both the duplex tube steam generator and the single tube steam generator have the same power rating, the duplex tube steam generator requires more tubes than the single tube steam generator because of the greater heat transfer resistance of the duplex tube, which is due to the presence of the helium gap. One should note that the MARS power station requires either 10 duplex tube steam generators or 10 single tube steam generators. The unavailability analysis below is applied only to one, isolated steam generator.

In the first part of our analysis we determined the overall unavailability of the two designs. The overall unavailability is the sum of the unavailability calculated for each of the three accident scenarios. Using the values of the four probability factors as used in the Westinghouse analysis ($C_1 = 1/10$, $C_2 = 1/20$, $C_3 = 3/4$, $C_4 = 1/10$), the overall probability that a forced shutdown of the steam generator will occur (λ_{SG}) and the overall unavailability of the steam generator, in percent (E_{tot}), for the two steam generator designs is as follows. For the duplex tube design:

$$\lambda_{SG} = 2.78 \times 10^{-5} \text{ hr}^{-1}$$

and

$$E_{tot} = 0.70\%$$

For the single tube design:

$$\lambda_{SG} = 2.3 \times 10^{-5} \text{ hr}^{-1}$$

$$E_{\text{tot}} = 4.2\% .$$

What this means is that although both designs show roughly the same overall probability that a forced shutdown will occur, the overall percentage of time that the steam generator can be expected to be inoperable due to a forced shutdown is significantly smaller for the duplex tube design. This is because the overall probability that a forced shutdown will occur is due mainly to a detected leak but no reaction accident scenario ($\lambda = 2.75 \times 10^{-5} \text{ hr}^{-1}$), for the duplex tube design. The probability of a small leak, small reaction is $2.7 \times 10^{-7} \text{ hr}^{-1}$, and the probability of a large leak, large reaction is $1.6 \times 10^{-8} \text{ hr}^{-1}$. Because the largest portion of the probability of forced shutdown is due to the detected leak but no reaction scenario, which has a relatively short repair time, the overall unavailability of the duplex tube design will be due mainly to the detected leak but no reaction scenario. Thus, this analysis demonstrates the effectiveness of the leak detection component of the duplex tube design.

In the second part of our analysis, we determined the sensitivity of the calculated unavailability of the two designs, to the variation of the four probability factors used in the Westinghouse analysis. Specifically, we calculated the unavailability of the two designs when one of the four probability factors is varied, while the other three factors are held constant at the values used in the Westinghouse analysis.

The first factor varied is the factor that determines the probability that the outer tube, of the duplex tube, fails. The value used by Westinghouse for this factor is 1/10. This means that the probability that the outer tube will fail is 1/10 of the probability that the inner tube will

fail. As this factor is increased from 0.1 to 1.0, the total unavailability of the duplex tube design increases from 0.7% to 1.7%, which is still significantly less than the unavailability of the single tube design (4.2%). Thus, even if the outer tube fails with the same probability of the inner tube, the duplex tube design is far superior than the single tube design.

The second factor varied is the factor that determines the probability that the inner tube will fail, due to the failure of the outer tube. As this factor is increased from the value used in the Westinghouse analysis ($C_2 = 0.05$) to 1.0, the unavailability of the duplex tube design increases from 0.7% to 1.3%. The third factor varied is the factor that determines the probability that the outer tube will fail, due to the failure of the inner tube (C_3). In this case, as the factor is varied from 0 to 1.0, the unavailability of the duplex tube design does not vary appreciably from 0.7%. Thus the overall unavailability of the duplex tube steam generator is not very sensitive to interdependent failures.

The last factor varied is the factor that determines the probability that a small break will deteriorate into a large break (C_4). For the duplex tube design, as the value of C_4 varies from 0 to 1.0, the overall unavailability varies, roughly linearly with C_4 , from 0.69% to 1.0%. For the single tube design, as the value of C_4 varies from 0 to 1.0, the overall unavailability varies, roughly linearly with C_4 , from 2.3% to 18.4%. Again, this demonstrates the effectiveness of the duplex tube with leak detection design, because even if every small break and localized reaction deteriorates into a large break and extensive reaction, the overall unavailability of the duplex tube steam generator is still only 1.0%. This is because the bulk of this unavailability is due to the detection of the leak but no reaction scenario.

Thus, if a leak is detected, more often than not, the steam generator will be shut down before the leak deteriorates into a break and a subsequent reaction.

In conclusion, although the duplex tube design produces no advantage over the single tube design, in lowering the probability of a forced shutdown due to a tube failure, the effect of a tube failure on the overall unavailability of the duplex tube design is significantly lower than the effect of a tube failure on the overall unavailability of the single tube design. The effect of the leak detection capability of the duplex tube design is to significantly reduce the overall unavailability of the duplex tube steam generator design by stopping most tube failures before they can deteriorate into a tube break and subsequent reaction, which could severely damage the steam generator.

The final step in the assessment of the reliability and availability of the steam generator will be to provide an extensive test of the steam generator to verify the conclusions of this analysis. Westinghouse is currently building a 70 MW full scale liquid-metal steam generator to verify their quantitative analysis. Their current program schedule states that they will complete the 70 MW steam generator at the end of this year, and begin testing early next year. Therefore the verification of their quantitative analysis should come within the next two years.

APPENDIX B

MARSBURN USER GUIDE

This appendix is intended as a manual describing the structure and formula derivation of the MARSBURN computer program for the interested reader, and as a guide for the program user. This appendix is divided into three sections. The first section contains a handbook describing the structure and formula derivation of the main subroutines in the program. The second section, the user guide, contains a printout of the terminal display from a typical run through the program along with an analysis of this display. The last section is a program listing.

B.1 Program Description

This section is designed to give the reader an overview of the program structure and of the interrelation of the program subroutines. To obtain the best understanding of the program structure, the reader is referred to Section 3 of this appendix, the program listing. This first section should only be used to elucidate the comment lines in the program listing. This section is divided into subsections, headed by subroutine names, each of which refer to that subroutine.

The program is written in FORTRAN. The definition and unit designation of program variables is given in a list at the beginning of the program. The program variables are in MKS units, except for mass which is often expressed in moles instead of kilograms.

B.1.1 Subroutine DRIVE

This subroutine controls the action of the mass balance subroutine (MDRIVE) and the energy balance subroutines (ENERRZ and ENERNZ). It keeps

track of the time from accident initiation and uses this to determine whether or not the calculation should proceed, by the action of a DO WHILE loop. During each pass through the loop, the mass and energy balances are iterated upon until the end of timestep pressure and temperature satisfy six conditions. The first of these conditions is that the end of timestep pressure cannot be greater than the average of the beginning of timestep pressure and the steam tube ambient pressure. This keeps the flow rate of water from the broken steam tube, which is a function of the difference between the steam tube ambient and the system pressure, from changing too rapidly during the timestep. The second condition is that the system pressure does not exceed the steam tube ambient pressure, in accordance with the assumption of no back-flow through the broken steam tube. The third condition is that the system pressure as calculated by the mass balance subroutine is close to the system pressure as calculated with the end of timestep reaction zone temperature. The fourth condition is that the reaction zone temperature cannot fall below the nonreaction zone temperature. The fifth condition is that neither the reaction nor the nonreaction zone temperature can fall below 648 K, which is the ambient water temperature in the unbroken steam tubes. This condition makes sure that the unbroken steam tubes will transfer energy out of the system by forced convection. The sixth and final condition is that if the timestep decreases to below 1×10^{-12} s, the program execution halts, and a message that this condition has been invoked is sent to the user's terminal. This condition is invoked when the reaction and nonreaction zone temperatures converge to the same temperature which causes either the fourth or fifth conditions to be invoked repeatedly. Each time the fourth or fifth condition

is invoked, the timestep is halved and the loop is reiterated. Thus, this last condition is meant to avoid the possibility of an endless loop.

B.1.2 Subroutine MDRIVE

Each time a call is made to MDRIVE, the reaction and nonreaction zone mass balances are carried out over ten equal time intervals for the current timestep. This is done because the reaction rate, and hence system pressure, depend upon the flow rate of water into the system and the flow of unreacted liquid-metal breeder out of the system, which in turn both depend upon the system pressure. This interrelation of the mass balances and reaction rate, through the system pressure, deems necessary the increased accuracy gained by carrying out the mass balances 10 times for each time the energy balances are carried out.

The mass balance is divided between two subroutines, FLOWRT and MASS.

B.1.3 Subroutine FLOWRT

This subroutine calculates the flow rate and specific energy of water from the broken steam tube by use of the homogeneous equilibrium model. The flow rate of steam and liquid H_2O was determined at 14 different pressures. Linear interpolation formulas were then derived for pressures between these 14 points.

B.1.4. Subroutine MASS

This subroutine calculates the reaction and nonreaction zone mass balances given the flow rate of H_2O into the reaction zone. The amount of liquid-metal breeder flowing into the reaction zone and reacting is determined by the amount of H_2O flowing into the reaction zone through the mixing parameter x . From the system pressure, the flow rate of unreacted liquid-metal breeder through the pressure relief valve can be determined, and thus the

nonreaction zone mass balance can be carried out. On the basis of these balances, the new reaction and nonreaction zone volume and system pressure is then determined. This new pressure can then be used during the next time the mass balances are calculated. Thus for each call made to MDRIVE, the mass balances are calculated 10 times, each time based on the pressure determined from the previous time the mass balances were calculated.

B.1.5 Subroutine ENERRZ

This subroutine solves the reaction zone energy balance:

$$\frac{dE_R}{dt} = -Q_c - Q_r - p \frac{dV_r}{dt} + \dot{m}_{br} i_b + \dot{m}_w i_w . \quad (10)$$

First, the energy flow terms on the right hand side of this equation over the timestep interval Δt are determined. Then, with the beginning of timestep reaction zone energy (E_{Ri}), the end of timestep reaction zone energy (E_{Rf}) can be determined:

$$E_{Rf} = E_{Ri} + \Delta t(-Q_c - Q_r - p \frac{dV_r}{dt} + \dot{m}_{br} i_b + \dot{m}_w i_w) . \quad (11)$$

Using the temperature derivative of the above equation, the end of timestep temperature of the reaction zone (T_{rf}) is then determined with Newton's method for determining the roots of an equation. This process is carried out by the subroutine ROOT.

The nonreaction zone energy balance is solved by the subroutine ENERNZ in the same manner as outlined above.

B.2 User Guide

This section contains a printout of the interactive terminal display from a typical run through the program, along with a printout containing a portion of the output from the run. The following page contains the terminal display. The arrows in the right hand margin point to the inputs provided by the user corresponding to program prompts. The letter (I) implies that the input must be an integer, and the letter (D) implies that the input must be double precision. The page after that contains the output from the run.

When the program is run interactively, the program first sends to the terminal the default values of the main program variables (X, APRV, PPRV, TIMEND, NPIPES, VRO) and then prompts the user to decide if he wants to change the default values of these variables. As shown in the printout of the terminal display, during this run, the value of TIMEND was the only variable changed, by entering a 1 after the prompt. Entering any other integer after the prompt implies that the user is satisfied with the default value of the variable. These variables are defined as:

X - the mixing parameter, the program will run properly for any value of x between 0.4 and 5.4.

APRV - the area of the pressure relief value (m^2).

PPRV - the set point pressure at which the pressure relief valve opens (N/m^2).

TIMEND - the time length of the accident(s).

NPIPES - the number of broken pipes.

VRO - the initial volume of the reaction zone; this variable must be nonzero for the program to run properly (m^3).

The next program prompt asks the user to choose the type of breeder for the program run. If this prompt is answered with a 1, the program then

```

THE DEFAULT VALUE OF X = 1.000
THE DEFAULT VALUE OF APRV = 5.0000E-03 M2
THE DEFAULT VALUE OF PPRV = 1.7240E+05 PA
THE DEFAULT VALUE OF TIMEND = 10.00 SEC
THE DEFAULT VALUE OF NPIPES = 1
THE DEFAULT VALUE OF VR0 = 1.0000E-05 M3
ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT VALUE OF X
2
ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT VALUE OF APRV
2
ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT VALUE OF PPRV
2
ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT VALUE OF TIMEND
1
ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT VALUE OF NPIPES
2
ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT VALUE OF VR0
2
ENTER THE NEW VALUE OF TIMEND
1.
THE DEFAULT LIQUID METAL BREEDER IS LI-17 PB-93
IF YOU WANT TO ENTER THE PROPERTIES OF A DIFFERENT TYPE OF BREEDER
ENTER A 1
1
ENTER THE NEW BREEDER DENSITY - KG3
510.
ENTER THE NEW BREEDER HEAT OF FORMATION - J/MOLE
0.
ENTER THE NEW BREEDER THERMAL CONDUCTIVITY - W/M-K
50.
ENTER THE NEW BREEDER THERMAL DIFFUSIVITY - M2/SEC
2.320-5
ENTER THE NEW BREEDER ATOMIC FRACTION OF LI
1. E. ENTERING 1. IMPLIES A PURE LI BREEDER.
ENTERING .5 IMPLIES LI-50 PB-50 .
1.
ENTER A 1 IF YOU WANT GENERAL OUTPUT
1
ENTER A 1 IF THE GENERAL OUTPUT IS TO INCLUDE MOLAR COMPONENTS
OF THE REACTION ZONE AND THE FLOWRATES INTO AND OUT OF THE SYSTEM
1
ENTER A 1 IF THE GENERAL OUTPUT IS TO INCLUDE THE ENERGY STATUS OF THE TWO ZONES
1
ENTER A 1 IF YOU WANT DEBUG OUTPUT
2
PROGRAM EXECUTION NOW BEGINS
THERE ARE 22 LINES IN THESE OUTPUT FILES
TIME vs. TEMP OF R.Z. AND N.Z. IS IN LOGICAL UNIT NO. 11
TIME vs. PRESSURE IS IN LOGICAL UNIT NO. 12
TIME vs. MASS FLX IS IN LOGICAL UNIT NO. 13
TIME vs. H2O AND BREEDER FLOW RATES IS IN LOGICAL UNIT NO. 14
THE GENERAL OUTPUT FILE IS IN LOGICAL UNIT NO.20
THE DEBUG OUTPUT IS IN LOGICAL UNIT NO. 15

THE MAXIMUM PRESSURE = 1.4706E+07 N/M2
THE MAXIMUM REACTION ZONE TEMPERATURE = 2103. K
FOR X = 1.000 AND APRV = 5.0000E-03 M2
FORTRAN STOP

```

THE PROGRAM VARIABLES ARE :

THE MIXING PARAMETER	-----	1.000	
PRESSURE RELIEF VALVE AREA	---	5.0000E-03	M2
PRV PRESSURE SET POINT	-----	1.7240E+05	N/M2
CALCULATION END TIME	-----	1.000	SEC
NUNBER OF BROKEN STEAM TUBES		1	
THE INITIAL REACTION ZONE VOL		1.0000E-05	M3
THE BREEDER IS COMPOSED OF		100.0	% LI AND 0.0000E+00 % PS

END OF TIMESTEP TIME ----- 4.0052E-07 SEC

REACTION ZONE TEMPERATURE	---	2183.	K
NONREACTION ZONE TEMPERATURE		673.0	K

SYSTEM PRESSURE	-----	1.8031E+06	PA
-----------------	-------	------------	----

REACTION ZONE VOLUME	-----	1.0090E-05	M3
GAS VOLUME	-----	1.0085E-05	M3

MOLAR FLOWRATE - H2O	-----	722.1	MOLES/SEC
MOLAR FLOWRATE TO R.Z. - LMB		722.1	MOLES/SEC
MOLAR FLOWRATE OUT OF PRV	---	1.2992E+05	MOLES/SEC

MASS OF H2 IN R.Z.	-----	6.9398E-04	MOLES
MASS OF PD IN R.Z.	-----	0.0000E+00	MOLES
MASS OF UNREACTED LI IN R.Z.		0.0000E+00	MOLES
MASS OF UNREACTED H2O IN R.Z.		0.0000E+00	MOLES
MASS OF LIQH IN R.Z.	-----	3.4699E-04	MOLES

R.Z. EXPANSION VELOCITY	----	82.85	M/SEC
-------------------------	------	-------	-------

CONDUCTION ENERGY	-----	1.4237E+07	J/SEC
FLUID EXPANSION WORK	-----	2.4068E+05	J/SEC
ENERGY FLOW INTO R.Z.	-----	-1.4457E+08	J/SEC
ENERGY FLOW OUT OF N.Z.	----	1.9764E+09	J/SEC
CONVECTION ENERGY OUT OF R.Z.		68.30	J/SEC
CONVECTION ENERGY OUT OF N.Z.		5.9662E+09	J/SEC

FINAL ENERGY OF R.Z.	-----	-76.42	J
FINAL ENERGY OF N.Z.	-----	2.9293E+10	J

INITIAL ENERGY OF R.Z.	-----	0.0000E+00	J
INITIAL ENERGY OF N.Z.	-----	2.9290E+10	J

SUM OF ENERGY CHANGE TOTAL	---	-1258.	J
TOTAL INTERNAL ENERGY	-----	-1258.	J

prompts the user to enter the properties of the new breeder. The printout of the terminal display shows that the breeder chosen during this run was pure lithium.

Next, the program prompts the user to choose the type and composition of the output. If the user wants debug output, the program will then prompt the user to choose for which of the subroutines he wants debug output.

After the program is executed, the program alerts the user to the location of the standard output files, the general output file, and the debug output file. The program then tells the user the maximum system pressure and reaction zone temperature reached during the run.

The standard output files are composed of lists of numbers without comment. Each line of output in logical unit number 11 consists of the time (s), temperature of the reaction zone (K), and temperature of the nonreaction zone (K). Each line of output in logical unit number 12 consists of the time (s) and the system pressure (N/m^2). Each line of output in logical unit number 13 consists of the time (s) and the mass of H_2 in the reaction zone (mole). Each line of output in logical unit 14 consists of the time (s), the molar flow rate of H_2O into the system (mole/s), and the molar flow rate of unreacted liquid-metal breeder out of the system (mole/s). All quantities in the standard output files are end of timestep quantities. A line is sent to each of these files every time a pass is made through the controlling DO-loop.

The composition of the general output file is shown on the second page of printout. This page shows the general output generated for the first pass through the controlling DO-loop. At the top of the general output file, the program variables chosen for the execution of the program are given. The first portion of the output generated for each pass through the controlling

D0-loop is self-explanatory. The R.Z. expansion velocity is simply a measure of how quickly the boundary between the reaction zone and nonreaction zone is expanding through the system. It equals the difference between the end of timestep reaction zone radius and the beginning of timestep reaction zone radius divided by the timestep. The next 10 lines refer to quantities in the reaction zone energy balance

$$E_{Rf} = E_{Ri} + \Delta t(-Q_c - Q_r - p \frac{dV_r}{dt} + \dot{m}_{br}i_b + \dot{m}_w i_w) \quad (B.1)$$

and the nonreaction zone energy balance

$$E_{Nf} = E_{Ni} + \Delta t(Q_c - Q_n - p \frac{dV_n}{dt} - \dot{m}_{br}i_b - \dot{m}_{bp}i_b) \quad (B.2)$$

where

Q_c = conduction energy

$p \frac{dV_r}{dt}$ = fluid expansion work

$\dot{m}_{br}i_b + \dot{m}_w i_w$ = energy flow into R.Z.

$\dot{m}_{br}i_b + \dot{m}_{bp}i_b$ = energy flow out of N.Z.

Q_r = convection energy out of R.Z.

Q_n = convection energy out of N.Z.

E_{Rf} = final energy of R.Z.

E_{Nf} = final energy of N.Z.

E_{Ri} = initial energy of R.Z.

E_{Ni} = initial energy of N.Z.

The last two lines in the output are an internal check to show that energy is being conserved. If Eqs. (B.1) and (B.2) are added together, the resulting equation is

$$E_{Rf} - E_{Ri} + E_{Nf} - E_{Ni} = \Delta t(-Q_r - Q_n + \dot{m}_w i_w - \dot{m}_{bp} i_{bp}) . \quad (B.3)$$

If both sides of this equation are summed for each timestep j , then the equation becomes

$$\sum_j (E_{Rfj} - E_{Rij} + E_{Nfj} - E_{Nij}) = \sum_i \Delta t_j (-Q_{rj} - Q_{nj} + \dot{m}_{wj} i_{wj} - \dot{m}_{bpj} i_{bpj}) . \quad (B.4)$$

If one notes that the initial energy of one timestep equals the final energy of the previous timestep, i.e.

$$E_{Rij} = E_{Rf(j-1)} \quad (B.5)$$

and
$$E_{Nij} = E_{Ni(j-1)} , \quad (B.6)$$

then the left hand side of Eq. (B.4) becomes

$$\sum_j (E_{Rfj} - E_{Rf(j-1)} + E_{Nfj} - E_{Nf(j-1)}) = E_{Rfj} - E_{Rf0} + E_{Nfj} - E_{Nf0} . \quad (B.7)$$

If one notes that the initial energy of the reaction zone, at the start of the calculation, is 0, then Eq. (B.4) can be written as

$$E_{Rfj} - E_{Nfj} - E_{Nf0} = \sum_j \Delta t_j (-Q_{rj} - Q_{nj} + \dot{m}_{wj} i_{wj} - \dot{m}_{bj} i_{bj}) . \quad (B.8)$$

The last two output lines correspond to the right hand side of Eq. (B.8) and the left hand side of Eq. (B.8), respectively. If energy is to be conserved by the program, the last two output lines must always be equal.

18-JUL-1984 00:20:42
18-JUL-1984 00:19:51

0115 C MPBI (*), MPBF (*) - moles of PB in the R. Z. at the b. o. t.
0116 C and e. o. t. (MOLE)
0117 C
0118 C
0119 C MPRVFR - molar flowrate of LMB out of the pressure relief
0120 C valve during the timestep. (MOLE/SEC)
0121 C
0122 C MSTM (*) - moles of steam flowing into the R. Z. during the
0123 C timestep (MOLE)
0124 C
0125 C NOUT - an internal count of the number of runs through the
0126 C driving DO loop.
0127 C
0128 C NPIPES - the number of broken steam tubes.
0129 C
0130 C PBREAK - the pressure at the steam tube break. (N/M2)
0131 C
0132 C PEND - penetration depth; a conduction length scale (M)
0133 C
0134 C PEPS - the pressure epsilon; a convergence measure. (N/M2)
0135 C
0136 C PI (*), PF (*) - the b. o. t. and e. o. t. system pressure
0137 C (N/M2)
0138 C
0139 C PPRV - the set point pressure at which the pressure relief
0140 C valve ruptures. (N/M2)
0141 C
0142 C PVDOT - the product of the pressure and the time derivative
0143 C of the R. Z. volume. (J/SEC)
0144 C
0145 C QCOND - the conductive heat transfer between the reaction
0146 C and nonreaction zones. (J/SEC)
0147 C
0148 C QFCNZ - the convective heat transfer from the N. Z. to
0149 C unbroken steam tubes. (J/SEC)
0150 C
0151 C QFCRZ - the convective heat transfer from the R. Z. to
0152 C unbroken steam tubes. (J/SEC)
0153 C
0154 C RADRZI, RADRZF, RADAVG - the b. o. t., e. o. t., and average
0155 C R. Z. radius (M)
0156 C
0157 C SEH2OL - the specific energy of the liquid H2O. (J/MOLE)
0158 C
0159 C SEH2 - the specific energy of the H2 gas. (J/MOLE)
0160 C
0161 C SELI - the specific energy of the liquid LI. (J/MOLE)
0162 C
0163 C SELIOH - the specific energy of the LIOH. (J/MOLE)
0164 C
0165 C SEPB - the specific energy of the liquid PB. (J/MOLE)
0166 C
0167 C SESTM - the specific energy of the steam (J/MOLE)
0168 C
0169 C SUMQ - the time integral of the time rate of change of
0170 C system energy. (J)
0171 C

```

0172 C SUMU - the total system energy. ( J )
0173 C
0174 C TCLMB - the thermal conductivity of the LMB ( W/M-K )
0175 C
0176 C TDLMB - the thermal diffusivity of the LMB ( M2/SEC )
0177 C
0178 C TEMPNI (*), TEMPNF (*) - the b. o. t. and e. o. t. temper-
0179 C ature of the N. Z. ( K )
0180 C
0181 C TEMPRI (*), TEMPRF (*) - the b. o. t. and e. o. t. temper-
0182 C ature of the R. Z. ( K )
0183 C
0184 C TEPS - the temperature epsilon; a convergence measure. ( K )
0185 C
0186 C TIMEND - the length of the accident scenario. ( SEC )
0187 C
0188 C TVAP - the vaporization temperature of the superheated steam.
0189 C ( K )
0190 C
0191 C UMH2OI (*), UMH2OF (*) - the unreacted amount of H2O in the
0192 C R. Z. at the b. o. t. and e. o. t.
0193 C ( MOLE )
0194 C
0195 C UMLII (*), UMLIF (*) - the unreacted amount of LI in the R. Z.
0196 C at the b. o. t. and e. o. t. ( MOLE )
0197 C
0198 C UNZI, UNZF - the b. o. t. and e. o. t. internal energy of
0199 C the N. Z. ( J )
0200 C
0201 C UNZO - the internal energy of the system at the beginning
0202 C of the program ( J )
0203 C
0204 C URZI, URZF - the b. o. t. and e. o. t. internal energy of
0205 C the R. Z. ( J )
0206 C
0207 C VGASF - the volume of the gas in the R. Z. at the e. o. t.
0208 C ( M3 )
0209 C
0210 C VNRI (*) , VNRF (*) - the b. o. t. and e. o. t. volume of
0211 C the N. Z. ( M3 )
0212 C
0213 C VRI (*), VRF (*) - the b. o. t. and e. o. t. volume of the
0214 C R. Z. ( M3 )
0215 C
0216 C VTOT - total volume of the system. ( M3 )
0217 C
0218 C X - the mixing ratio; it is the ratio of the flow rate of
0219 C H2O to flow rate of LI that enters the R. Z. during
0220 C a timestep.
0221 C
0222 C XH2OHF - the heat of formation of the H2O. ( J/MOLE )
0223 C
0224 C XLCPRV - the loss coefficient of the pressure relief valve.
0225 C
0226 C XLMBHF - the heat of formation of the LMB. ( J/MOLE )
0227 C
0228 C

```

VAX-11 FORTRAN V3.5-62
DUA1:[NUKE.JIM]MARS PRG.;26

18-JUL-1984 00:20:42
18-JUL-1984 00:19:51

C*****
C This is the main driving routine of the MARSBURN program.
C*****

```

      IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
      IMPLICIT INTEGER ( I-L,N )
      PARAMETER ( IWRITE = 6 )
      PARAMETER ( IOUT = 20, ITEMP = 11, IPRES = 12, IMH2 = 13,
1        IFLOW = 14 )
      LOGICAL DEBUG(7)
      COMMON /DEB/ DEBUG, IDBOUT
      COMMON /INPUT/
2        X, APRV,
3        PPRV, XLCPRV,
4        DELTAI, TIMEND, NPIPES, VTOT,
      TEPS, PEPS, VRO
      COMMON /PROP/
1        DLMB, DLI0H, DLI, DPB,
2        XLMBHF,
3        TCLMB, TDLMB,
4        APLI

```

C First we set the default values for the common block
C variables.

C Beginning with INPUT.

X = 1.

APRV = .005

PPRV = 1.724D5

XLCPRV = 2.69

C This is equivalent to the constant in the equation for the
C critical velocity for flow through an orifice.

DELTAI = 1.D-4

TIMEND = 10.

NPIPES = 1

VTOT = 27.75

TEPS = 1.

PEPS = 1.D5

VRO = 1.D-5

C We must provide a volume at the beginning of the calculation for
C the first timestep water flow. This volume is equivalent to a
C spherical volume around the break with an effective radius of
C 1.34 cm. This radius is less than the tube pitch (1.84 cm).
C Therefore the original break volume is confined to the region
C of one tube.

C Now we set the default values for the PROP common block.

C The default liquid metal breeder is LI-17 PB-83.

DLMB = 8.976D3

DLI0H = 1.63D3

DLI = 510.

DPB = 1.071D4

XLMBHF = -1.422D4

TCLMB = 35.

TDLMB = 2.27D-5

APLI = .17

```

0286 C
0287 C The final default is the debug output logical unit number.
0288 C IDBOUT = 15
0289 C
0290 C Now we call the INCHNG (input change) subroutine which prompts
0291 C the user to set the rest of the common block variables and
0292 C allows the user to change the default value of some of the
0293 C common block variables.
0294 C CALL INCHNG
0295 C
0296 C Now we set the initial values of program variables for the
0297 C first timestep.
0298 C TEMPRI = 673.
0299 C TEMPNI = 673.
0300 C PI = 1.724D5
0301 C VNRI = VTOT - VRO
0302 C VRI = VRO
0303 C MPBI = 0.
0304 C UMLII = 0.
0305 C UMH2OI = 0.
0306 C MLIOHI = 0.
0307 C MINERT = PI * VRO / ( TEMPRI * 8.314 )
0308 C This is the initial gas in the reaction zone since the
0309 C initial reaction zone volume must be nonzero. The gas is inert
0310 C and is only present to keep the pressure calculations consistent.
0311 C MH2I = 0.
0312 C DELTAT = DELTAI
0313 C NOUT = 0
0314 C NFLAG = 0
0315 C
0316 C WRITE ( IWRITE,110 )
0317 C FORMAT ( ' PROGRAM EXECUTION NOW BEGINS ' )
0318 C We are now ready to call the driving subroutine.
0319 C CALL DRIVE (
0320 C 1 TEMPRI, TEMPNI, PI, VNRI, VRI,
0321 C 1 MPBI, UMLII, UMH2OI, MLIOHI, MH2I, MINERT,
0322 C 2 DELTAT, NOUT, NFLAG,
0323 C 3 PMAX, TMAX )
0324 C
0325 C WRITE ( IWRITE,100 ) NOUT, ITEMPI, IPRES, IMH2, IFLOW
0326 C FORMAT ( ' THERE ARE ',I5,' LINES IN THESE OUTPUT FILES' /
0327 C 1 ' TIME vs. TEMP OF R.Z. AND N.Z. IS IN LOGICAL UNIT NO. ',
0328 C 2 I2 / ' TIME vs. PRESSURE IS IN LOGICAL UNIT NO. ',I2 /
0329 C 3 ' TIME vs. MASS H2 IS IN LOGICAL UNIT NO. ', I2 /
0330 C 4 ' TIME vs. H2O AND BREEDER FLOW RATES IS IN LOGICAL ',
0331 C 5 ' UNIT NO. ', I2 )
0332 C
0333 C WRITE ( IWRITE,101 ) IOUT, IDBOUT
0334 C FORMAT ( ' THE GENERAL OUTPUT FILE IS IN LOGICAL UNIT',
0335 C 1 ' NO. ', I2 / ' THE DEBUG OUTPUT IS IN LOGICAL UNIT',
0336 C 2 ' NO. ', I2 )
0337 C WRITE ( IWRITE,102 ) PMAX, TMAX, X, APRV
0338 C FORMAT ( ' 5X/10X, 'THE MAXIMUM PRESSURE = ',IP1G11.4,
0339 C 1 ' N/M2 / 10X, 'THE MAXIMUM REACTION ZONE',
0340 C 2 ' TEMPERATURE = ',IP1G11.4,' K' / 10X, 'FOR X = ',
0341 C 3 IP1G11.4, ' AND APRV = ',IP1G11.4, ' M2 ' )
0342 C

```

18-JUL-1984 00:20:42 VAX-11 FORTRAN V3.5-62
18-JUL-1984 00:19:51 DUA1:[NUKE.JIM]MARSPRG.;26

MARSPRG\$MAIN

```

0343 C      That's all folks!
0344      STOP
0345      END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	557	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	577	PIC CON REL LCL SHR NOEXE RD NOWRT LONG
2 \$LOCAL	188	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
3 DEB	32	PIC OVR REL GBL SHR NOEXE RD WRT LONG
4 INPUT	84	PIC OVR REL GBL SHR NOEXE RD WRT LONG
5 PROP	64	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	1502	

ENTRY POINTS

Address	Type	Name
0-00000000		MARSPRG\$MAIN

VARIABLES

Address	Type	Name	Address	Type	Name
5-00000038	R*8	APLI	4-00000020	R*8	DELTAI
5-00000010	R*8	DLI	5-00000000	R*8	DLMB
3-0000001C	I*4	IDBOUT	2-00000048	R*8	MINERT
2-00000028	R*8	MPBI	2-00000070	I*4	NOUT
4-00000044	R*8	PEPS	2-00000060	R*8	PMAX
5-00000028	R*8	TCLMB	2-00000008	R*8	TEMPNI
4-0000003C	R*8	TEPS	2-00000068	R*8	TMAX
2-00000030	R*8	UMLII	4-0000004C	R*8	VRO
4-00000034	R*8	VTOT	4-00000018	R*8	XLCPRV
			2-00000058	R*8	DELTAT
			5-00000018	R*8	DPB
			2-00000040	R*8	MLIOHI
			4-00000030	I*4	NPIPES
			4-00000010	R*8	PPRV
			2-00000000	R*8	TEMPRI
			2-00000038	R*8	UMH20I
			2-00000020	R*8	VRI
			5-00000020	R*8	XLMBHF

ARRAYS

Address	Type	Name	Bytes	Dimensions
3-00000000	L*4	DEBUG	28	(7)

LABELS

Address	Label	Address	Label
1-00000036	100'	1-00000145	101'
		1-00000180	102'
		1-00000014	110'

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name
DRIVE		INCHG	

```

0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C
0029 C
0030 C
0031 C
0032 C
0033 C
0034 C
0035 C
0036 C
0037 C
0038 C
0039 C
0040 C
0041 C
0042 C
0043 C
0044 C
0045 C
0046 C
0047 C
0048 C
0049 C
0050 C
0051 C
0052 C
0053 C
0054 C
0055 C
0056 C
0057 C

SUBROUTINE INCHNG

      This subroutine sets the values of the logical vector
      DEBUG, the common block OUT, and allows the user to change
      the default values of X, APRV, PPRV, TIMEND, NPIPES, VRO,
      DLMB, XLMBHF, TCLMB, TDLMB, and APLI.
      IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
      INTEGER ( I-L,N )
      CHARACTER*6 CINPUT(7)
      CHARACTER*6 NAME(7)
      LOGICAL DEBUG(7)
      COMMON /DEB/ DEBUG, IDBOUT
      COMMON /OUT/ JOUT1, JOUT2, JOUT3
      COMMON /INPUT/

1 X, APRV,
2 PPRV, XLCPRV,
3 DELTAI, TIMEND, NPIPES, VTOT,
4 TEPS, PEPS, VRO
      COMMON /PROP/

1 DLMB, DLIOH, DLI, DPB,
2 XLMBHF,
3 TCLMB, TDLMB,
4 APLI
      PARAMETER ( IREAD = 5, IWRITE = 6 )

      First we set the character arrays NAME and CINPUT.
      NAME(1) = 'DRIVE'
      NAME(2) = 'MDRIVE'
      NAME(3) = 'MASS'
      NAME(4) = 'ENERRZ'
      NAME(5) = 'ROOT'
      NAME(6) = 'PCONTL'
      NAME(7) = 'ENERNZ'

      CINPUT(1) = 'X'
      CINPUT(2) = 'APRV'
      CINPUT(3) = 'PPRV'
      CINPUT(4) = 'TIMEND'
      CINPUT(5) = 'NPIPES'
      CINPUT(6) = 'VRO'

      Now we see if the user wants to change any default values.
      WRITE ( IWRITE,100 ) X, APRV, PPRV, TIMEND, NPIPES, VRO
100 FORMAT ( 10X/
1 , THE DEFAULT VALUE OF X = ,1P1G11.4/
2 , THE DEFAULT VALUE OF APRV = ,1P1G11.4,' M2' /
3 , THE DEFAULT VALUE OF PPRV = ,1P1G11.4,' PA' /
4 , THE DEFAULT VALUE OF TIMEND = ,1P1G11.4,' SEC' /
5 , THE DEFAULT VALUE OF NPIPES = ,I3 /
6 , THE DEFAULT VALUE OF VRO = ,1P1G11.4,' M3' )

```

```

0058 DO 10 I = 1,6
0059   WRITE ( IWRITE,101 ) CINPUT(I)
0060   FORMAT( ' ENTER A 1 IF YOU WANT TO CHANGE THE DEFAULT',
0061     ' VALUE OF ', 6A )
0062   READ ( IREAD,* ) IINPUT(I)
0063 C
0064   CONTINUE
0065 C
0066   IF ( IINPUT(1).EQ.1 ) THEN
0067     WRITE ( IWRITE,102 )
0068     FORMAT ( ' ENTER THE NEW VALUE OF X' )
0069     READ ( IREAD,* ) X
0070     END IF
0071 C
0072   IF ( IINPUT(2).EQ.1 ) THEN
0073     WRITE ( IWRITE,103 )
0074     FORMAT ( ' ENTER THE NEW VALUE OF APRV' )
0075     READ ( IREAD,* ) APRV
0076     END IF
0077 C
0078   IF ( IINPUT(3).EQ.1 ) THEN
0079     WRITE ( IWRITE,104 )
0080     FORMAT ( ' ENTER THE NEW VALUE OF PPRV' )
0081     READ ( IREAD,* ) PPRV
0082     END IF
0083 C
0084   IF ( IINPUT(4).EQ.1 ) THEN
0085     WRITE ( IWRITE,105 )
0086     FORMAT ( ' ENTER THE NEW VALUE OF TIMEND' )
0087     READ ( IREAD,* ) TIMEND
0088     END IF
0089 C
0090   IF ( IINPUT(5).EQ.1 ) THEN
0091     WRITE ( IWRITE,106 )
0092     FORMAT ( ' ENTER THE NEW VALUE OF NPIPES' )
0093     READ ( IREAD,* ) NPIPES
0094     END IF
0095 C
0096   IF ( IINPUT(6).EQ.1 ) THEN
0097     WRITE ( IWRITE,107 )
0098     FORMAT ( ' ENTER THE NEW VALUE OF VR0' )
0099     READ ( IREAD,* ) VR0
0100     END IF
0101 C
0102   Now for the choice of the liquid metal breeder.
0103   WRITE ( IWRITE,110 )
0104   FORMAT ( ' THE DEFAULT LIQUID METAL BREEDER IS LI-17',
0105     ' PB-83', / , ' IF YOU WANT TO ENTER THE PROPERTIES OF',
0106     ' A DIFFERENT TYPE OF BREEDER ', /
0107     ' ENTER A 1' )
0108   READ ( IREAD,* ) IINPUT(7)
0109 C
0110   IF ( IINPUT(7).EQ.1 ) THEN
0111     WRITE ( IWRITE,111 )
0112     FORMAT ( ' ENTER THE NEW BREEDER DENSITY - KG3 ' )
0113     READ ( IREAD,* ) DLMB
0114 C

```

```

0115 WRITE ( IWRITE,112 )
0116 FORMAT ( ' ENTER THE NEW BREEDER HEAT OF FORMATION ' ,
0117 ' - J/MOLE ' )
0118 READ ( IREAD,* ) XLMBHF
0119 C
0120 WRITE ( IWRITE,113 )
0121 FORMAT ( ' ENTER THE NEW BREEDER THERMAL CONDUCTIVITY',
0122 ' - W/M-K ' )
0123 READ ( IREAD,* ) TCLMB
0124 C
0125 WRITE ( IWRITE,114 )
0126 FORMAT ( ' ENTER THE NEW BREEDER THERMAL DIFFUSIVITY ' ,
0127 ' - M2/SEC ' )
0128 READ ( IREAD,* ) TDLMB
0129 WRITE ( IWRITE,115 )
0130 FORMAT ( ' ENTER THE NEW BREEDER ATOMIC FRACTION OF LI'
0131 / 5X, 'I. E. ENTERING 1. IMPLIES A PURE LI',
0132 ' BREEDER.' / 5X, 'ENTERING .5 IMPLIES LI-50',
0133 ' PB-50 . . ' )
0134 READ ( IREAD,* ) APLI
0135 C
0136 END IF
0137 C
0138 C Now we set the type of output wanted for this run.
0139 WRITE ( IWRITE,200 )
0140 FORMAT ( ' ENTER A 1 IF YOU WANT GENERAL OUTPUT' )
0141 READ ( IREAD,* ) JOUT1
0142 C
0143 IF ( JOUT1.NE. 1 ) GO TO 55
0144 WRITE ( IWRITE,201 )
0145 FORMAT( ' ENTER A 1 IF THE GENERAL OUTPUT IS TO INCLUDE ' ,
0146 ' MOLAR COMPONENTS' / ' OF THE REACTION ZONE AND THE',
0147 ' FLOWRATES INTO AND OUT OF THE SYSTEM' )
0148 READ ( IREAD,* ) JOUT2
0149 C
0150 WRITE ( IWRITE,202 )
0151 FORMAT( ' ENTER A 1 IF THE GENERAL OUTPUT IS TO INCLUDE',
0152 ' THE ENERGY STATUS OF THE TWO ZONES.' )
0153 READ ( IREAD,* ) JOUT3
0154 CONTINUE
0155 C
0156 C Finally we set the debug switches.
0157 WRITE ( IWRITE,300 )
0158 FORMAT ( ' ENTER A 1 IF YOU WANT DEBUG OUTPUT ' )
0159 READ ( IREAD,* ) JOUT4
0160 C
0161 C
0162 IF ( JOUT4.EQ. 1 ) THEN
0163 DO 20 I = 1,7
0164 WRITE ( IWRITE,301 ) NAME(I)
0165 FORMAT ( ' ENTER A 1 IF YOU WANT DEBUG OUTPUT',
0166 ' FOR SUBROUTINE ' , 6A )
0167 READ ( IREAD,* ) IDEBUG(I)
0168 C
0169 IF ( IDEBUG(I).EQ. 1 ) THEN
0170 DEBUG(I) = .TRUE.
0171

```

```

0172      ELSE
0173      DEBUG(I) = .FALSE.
0174      END IF
0175      CONTINUE
0176      END IF
0177      C
0178      C      That's all folks!
0179      RETURN
0180      END

```

PROGRAM SECTIONS

Name	Bytes	Attributes	
0 \$CODE	1246	PIC CON REL LCL	SHR EXE RD NOWRT LONG
1 \$PDATA	1434	PIC CON REL LCL	SHR NOEXE RD NOWRT LONG
2 \$LOCAL	152	PIC CON REL LCL	NOSHR NOEXE RD WRT LONG
3 DEB	32	PIC OVR REL GBL	SHR NOEXE RD WRT LONG
4 OUT	12	PIC OVR REL GBL	SHR NOEXE RD WRT LONG
5 INPUT	84	PIC OVR REL GBL	SHR NOEXE RD WRT LONG
6 PROP	64	PIC OVR REL GBL	SHR NOEXE RD WRT LONG
Total Space Allocated	3024		

ENTRY POINTS

Address	Type	Name
0-00000000		INCHNG

VARIABLES

Address	Type	Name	Address	Type	Name
6-00000038	R*8	APLI	5-00000020	R*8	DELTAI
6-00000008	R*8	DLIOH	6-00000018	R*8	DPB
3-0000001C	I*4	IDBOUT	4-00000004	I*4	JOUT2
2-0000008C	I*4	JOUT4	5-00000044	R*8	PEPS
6-00000028	R*8	TCLMB	5-0000003C	R*8	TEPS
5-0000004C	R*8	VRO	5-00000000	R*8	X
6-00000020	R*8	XLMBHF			
			6-00000010	R*8	DLI
			2-00000088	I*4	I
			4-00000008	I*4	JOUT3
			5-00000010	R*8	PPRV
			5-00000028	R*8	TIMEND
			5-00000018	R*8	XLCPRV

ARRAYS

Address	Type	Name	Bytes	Dimensions
2-00000038	CHAR	CINPUT	36	(6)
3-00000000	L*4	DEBUG	28	(7)
2-00000000	I*4	IDEBUG	28	(7)
2-0000001C	I*4	IINPUT	28	(7)
2-0000005C	CHAR	NAME	42	(7)

LABELS

Address	Label	Address	Label	Address	Label	Address	Label	Address	Label	Address	Label	Address	Label
**	10	**	20	0-0000043A	55	1-00000000	100'	1-000000F7	101'	1-00000135	102'		
1-00000151	103'	1-00000170	104'	1-0000018F	105'	1-000001B1	106'	1-000001D2	107'	1-000001F0	110'		
1-0000027E	111'	1-000002A6	112'	1-000002DD	113'	1-00000315	114'	1-0000034E	115'	1-000003DF	200'		
1-00000407	201'	1-00000493	202'	1-000004EA	300'	1-00000511	301'						

```

0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C
0029 C
0030 C
0031 C
0032 C
0033 C
0034 C
0035 C
0036 C
0037 C
0038 C
0039 C
0040 C
0041 C
0042 C
0043 C
0044 C
0045 C
0046 C
0047 C
0048 C
0049 C
0050 C
0051 C
0052 C
0053 C
0054 C
0055 C
0056 C
0057 C

      SUBROUTINE DRIVE (
1 TEMPRI, TEMPNI, PI, VNRI, VRI,
1 MPBI, UMLII, UMH2OI, MLIOHI, MH2I, MINERT,
2 DELTAT, NOUT, NFLAG,
3 PMAX, TMAX )

C
C This subroutine contains the driving do loop. It also calls
C the mass balance subroutine (MDRIVE),
C the reaction zone energy balance (ENERRZ), and the nonreaction zone
C energy balance (ENERNZ). It also contains statements that adjust
C the length of the timestep (DELTAT) depending upon the size of the
C pressure change over the timestep. Finally, it calls the sub-
C routine OUTPUT.
      IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
      IMPLICIT INTEGER ( I-L,N )
      DOUBLE PRECISION P(10), VRF(10)
      LOGICAL DEBUG(7)
      PARAMETER ( IWRITE = 6 )
      COMMON /DEB/ DEBUG, IDBOUT
      COMMON /INPUT/
1 X, APRV,
2 PPRV, XLCPRV,
3 DELTAI, TIMEND, NPIPES, VTOT,
4 TEPS, PEPS, VRO
      COMMON /PROP/
1 DLMB, DLIOH, DLI, DPB,
2 XLMBHF,
3 TCLMB, TDLMB,
4 APLI

C
C To begin we set up the do loop.
      IPRV = 0
      TIME = 0.

      SUMQ = 0.
      MNZO = VNRI * DLMB / ( ( 1 - APLI ) * .20721 +
1 APLI * 6.94D-3 )
      PDUM = 0.

C
C The above PDUM is a dummy variable, used to tell SENER not
C to carry out the equations to determine the specific energy of
C the water, since that information will not be needed here.
      CALL SENER (
1 TEMPNI, PDUM,
2
3 SEH2, SELIOH, SEH2O, SEPB, SELI,
3 DSEH2, DSLIOH, DSEH2O, DSEPB, DSELI )
      UNZO = MNZO * ( ( 1 - APLI ) * SEPB + APLI *
1 SELI + XLMBHF )

C
      URZI = 0.
      UNZI = UNZO

```

DRIVE

```

0058 C
0059 C
0060 DO 100 WHILE ( TIME .LE. TIMEND )
0061 TEMPV = TEMPRI
0062 CONTINUE
0063
0064 200
0065 C
0066 C First a call to the mass balance subroutine.
0067 CALL MDRIVE (
0068 1 TEMPV, MPBI, UMLII, UMH2OI, MLIOHI, MH2I, VNRI, PI, IPRV,
0069 1 VRI, MINERT,
0070 2 DELTAT,
0071 3 MH2O, MSTM, MLMB, MPBF, UMLIF, UMH2OF, MLIOHF, MH2F,
0072 3 FRPV, VNRV, VRF, VGASF, P, ICONTL, SESTM, SEH2OL )
0073 IF ( ICONTL.EQ.1 ) GO TO 200
0074 C This condition checks to see if DELTAT was adjusted during the
0075 C execution of MDRIVE. If it has, MDRIVE is reexecuted until
0076 C DELTAT is not adjusted during execution of MDRIVE.
0077 C
0078 C Now the call to the reaction zone energy balance.
0079 CALL ENERRZ (
0080 1 TEMPRI, TEMPNI, DELTAT, PI, P, VRF, MPBI, UMLII,
0081 1 UMH2OI, MLIOHI, MH2I, MH2O, MSTM, MLMB, MPBF, UMLIF, UMH2OF,
0082 2 MLIOHF, MH2F, VRI, URZI, SESTM, SEH2OL,
0083 3 QCOND, PVDOT, URZF, ENGIN, QFCRZ, TEMPRF, DRDT )
0084 C
0085 C Now for the pressure control statements.
0086 C
0087 C First we determine the end of timestep pressure.
0088 PF = 8.314 * ( MH2F + MINERT + UMH2OF ) * TEMPRF / VGASF
0089 PCHECK = ( PI + 1.6543D7 ) * .5
0090 IF ( PF .GT. PCHECK ) THEN
0091 C If this condition is true, it means that the pressure has
0092 C increased more than half of the way to 1.6543D7 psia, which is the
0093 C water tube back pressure. This means that the system maybe
0094 C changing too rapidly over the timestep. To be prudent then, the
0095 C timestep is decreased by a call to PCONTL. And the balances are
0096 C recalculated.
0097 CALL PCONTL (
0098 1 PI, PF,
0099 2 DELTAT
0100 3 )
0101 IF ( DEBUG(1) ) THEN
0102 WRITE ( IDBOUT,1000 )
0103 FORMAT ( '***** PF is greater than PCHECK ' )
0104 WRITE ( IDBOUT,1001 ) PF, PCHECK
0105 FORMAT ( ' PF PCHECK / 1P2G11.4 )
0106 END IF
0107 GO TO 200
0108 END IF
0109 C
0110 IF ( DABS( PF - P(10) ) .GT. PEPS ) THEN
0111 C
0112 C If this condition is true, then calculating the mass balance
0113 C isothermally may not be good assumption. To correct this, we
0114 C recalculate the mass balance with a different temperature, which

```

C is the final reaction zone temperature over this last iteration.

```

0115 C
0116 C      TEMPAV = TEMPWF
0117 C
0118 C
0119 C      IF ( DEBUG(1) ) THEN
0120 C          WRITE ( IDBOUT,1003 ) PF, P(10)
0121 C          FORMAT ( ' PF P(10) / IP2G11.4 )
0122 C          WRITE ( IDBOUT,1002 )
0123 C          FORMAT ( ' ***** nonisothermal pressure ' )
0124 C          END IF
0125 C          GO TO 200
0126 C      END IF
0127 C
0128 C      The pressure control statements are now completed.
0129 C
0130 C      Now for the nonreaction zone energy balance.
0131 C
0132 C      IF ( NFLAG.EQ. 1 ) GO TO 300
0133 C      If this condition is true, then the nonreaction zone temper-
0134 C      ture has converged to the steam tube ambient temperature ( 648K ).
0135 C      In this case, the nonreaction zone temperature will remain
0136 C      at 648K, and it is not necessary to carry out the nonreaction
0137 C      zone energy balance.
0138 C      CALL ENERNZ (
0139 C          1 VNRI, VNRF, TEMPNI, DELTAT, PVDOT, QCOND, FRPRV, MLMB,
0140 C          1 UNZI,
0141 C          2
0142 C          3 UNZF, TEMPNF, ENGOUT, QFCNZ )
0143 C
0144 C
0145 C
0146 C
0147 C
0148 C      The first temperature control case is when TEMPWF and TEMPNF
0149 C      converge to one temperature and remain at this temperature.
0150 C      This is caused by either the value of X being too large or too
0151 C      small. This causes the reaction rate to be too small, so that
0152 C      the system reaches an equilibrium condition. This will cause
0153 C      the program to not work properly because the timestep decreases
0154 C      significantly. If this happens, we halt the program.
0155 C      IF ( DELTAT.LT. 1.D-12 ) THEN
0156 C          WRITE ( IWRITE,1004 ) TIME, TEMPWF, TEMPNF, PF
0157 C          FORMAT ( ' PROGRAM EXECUTION HALTED ', IP1G11.4,
0158 C              ' SECONDS INTO THE ACCIDENT', /5X, 'BECAUSE EQUILI',
0159 C              ' BRIUM WAS REACHED BETWEEN THE TWO ZONES - WITH: /'
0160 C              5X, 'REACTION ZONE TEMPERATURE = ', IP1G11.4 /
0161 C              5X, 'NONREACTION ZONE TEMPERATURE = ', IP1G11.4 /
0162 C              5X, 'SYSTEM PRESSURE = ', IP1G11.4 )
0163 C          GO TO 101
0164 C      END IF
0165 C
0166 C
0167 C
0168 C
0169 C
0170 C
0171 C

```

```

0172      300      CONTINUE
0173      C
0174      C      If the reaction temperature has fallen below the nonreaction
0175      C      zone temperature, the timestep is too large.
0176      C      IF ( TEMPNF .GE. TEMPRF ) THEN
0177      C          DELTAT = DELTAT * .5
0178      C          GO TO 200
0179      C      END IF
0180      C      To correct this, we must readjust the timestep size and
0181      C      return to the beginning of the loop.
0182      C
0183      C
0184      C
0185      C      SUMU = UNZF + URZF - UNZO
0186      C      SUMQ = DELTAT * ( ENGIN - ENGOUT - QFCRZ - QFCNZ )
0187      C          + SUMQ
0188      C      These are the sum of the energy changes in the reaction
0189      C      zone and nonreaction zone. If energy is conserved these will
0190      C      be equal.
0191      C
0192      C
0193      C      MH2OFR = MH2O / DELTAT
0194      C      MLMBFR = MLMB / DELTAT
0195      C      MPRVFR = FRPRV / ( ( 1 - APLI ) * .20721 + APLI * 6.94D-3 )
0196      C      These are the molar flowrates of H2O and LMB into the reaction
0197      C      zone, and LMB out of the pressure relief valve, respectively.
0198      C
0199      C      Now for the output routine.
0200      C      First we update TIME.
0201      C      TIME = TIME + DELTAT
0202      C      CALL OUTPUT (
0203      C          1 TIME, TEMPRF, TEMPNF, PF, VRF(10), VGASF, MH2OFR, MLMBFR,
0204      C          1 MPRVFR, MH2F, MPBF, UMLIF, UMH2OF, MLIOHF,
0205      C          1 QCOND, PVDOT, ENGOUT, ENGIN, URZF, UNZF, QFCRZ, QFCNZ,
0206      C          1 DRDT, SUMQ, SUMU, URZI, UNZI,
0207      C          2 NOUT, NFLAG, PMAX, TMAX
0208      C          3 )
0209      C
0210      C      Finally, we reset the loop.
0211      C      First we increase DELTAT. This is done so that the timestep
0212      C      does not remain smaller than it needs to be.
0213      C      DELTAT = 2. * DELTAT
0214      C      PI = PF
0215      C      VRI = VRF(10)
0216      C      VNRI = VNRF
0217      C      TEMPRI = TEMPRF
0218      C      TEMPNI = TEMPNF
0219      C      UMLII = UMLIF
0220      C      UMH2OI = UMH2OF
0221      C      MPBI = MPBF
0222      C      MLIOHI = MLIOHF
0223      C      MH2I = MH2F
0224      C      URZI = URZF
0225      C      UNZI = UNZF
0226      C      IF ( PI .GT. PPRV ) IPRV = 1
0227      C
0228      C      This condition checks to see if the rupture disk has opened
0229      C      during this pass through the do loop. If it has, IPRV is set

```

0229 C to 1, and remains set to 1 through the rest of the program
0230 C execution. This alerts the subroutine MASS that the disk has
0231 C ruptured.
0232 100 CONTINUE
0233 101 CONTINUE
0234 C That's all folks!
0235 RETURN
0236 END

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	966	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	352	PIC CON REL LCL SHR NOEXE RD NOWRT LONG
2 \$LOCAL	1044	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
3 DEB	32	PIC OVR REL GBL SHR NOEXE RD WRT LONG
4 INPUT	84	PIC OVR REL GBL SHR NOEXE RD WRT LONG
5 PROP	64	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	2542	

ENTRY POINTS

Address	Type	Name
0-00000000	DRIVE	

VARIABLES

Address	Type	Name	Address	Type	Name	Address	Type	Name
5-00000038	R*8	APLI	4-00000008	R*8	APRV	4-00000020	R*8	DELTAI
5-00000010	R*8	DLI	5-00000008	R*8	DLIOH	5-00000000	R*8	DLMB
2-000001C8	R*8	DRDT	2-000000E8	R*8	DSEH2	2-000000F8	R*8	DSEH20
2-00000100	R*8	DSEPB	2-000000F0	R*8	DSLIOH	2-000001B0	R*8	ENGIN
2-00000170	R*8	FRPRV	2-00000224	I*4	ICONTL	3-0000001C	I*4	IDBOUT
2-00000168	R*8	MH2F	AP-00000028@	R*8	MH2I	2-00000130	R*8	MH20
AP-0000002C@	R*8	MINERT	2-00000160	R*8	MLIOHF	AP-00000024@	R*8	MLIOHI
2-00000210	R*8	MLMBFR	2-000000B0	R*8	MNZO	2-00000148	R*8	MPBF
2-00000218	R*8	MPRVFR	2-00000138	R*8	MSTM	AP-00000038@	I*4	NFLAG
4-00000030	I*4	NPIPES	2-000001D8	R*8	PCHECK	2-000000B8	R*8	PDUM
2-000001D0	R*8	PF	AP-0000000C@	R*8	PI	AP-0000003C@	R*8	PMAX
2-000001A0	R*8	PVDOT	2-00000198	R*8	QCOND	2-000001F8	R*8	QFCNZ
2-000000C0	R*8	SEH2	2-000000D0	R*8	SEH20	2-00000190	R*8	SEH20L
2-0000000C8	R*8	SELIOH	2-000000D8	R*8	SEPB	2-00000188	R*8	SESTM
2-000000200	R*8	SUMU	5-00000028	R*8	TCLMB	5-00000030	R*8	TDLMB
2-000001E8	R*8	TEMPNF	AP-00000008@	R*8	TEMPNI	2-000001C0	R*8	TEMPRF
4-0000003C	R*8	TEPS	2-000000A0	R*8	TIME	4-00000028	R*8	TIMEND
2-00000158	R*8	UMH2OF	AP-00000020@	R*8	UMH2OI	2-00000150	R*8	UMLIF
2-00000110	R*8	UNZ0	2-000001E0	R*8	UNZF	2-00000120	R*8	UNZI
2-00000118	R*8	URZI	2-00000180	R*8	VGASF	2-00000178	R*8	VNRF
AP-00000030@	R*8							
5-00000018	R*8							
2-00000108	R*8							
2-000001F0	R*8							
2-00000220	I*4							
2-00000208	R*8							
2-00000140	R*8							
AP-00000018@	R*8							
AP-00000034@	I*4							
4-00000044	R*8							
4-00000010	R*8							
2-000001B8	R*8							
2-000000E0	R*8							
2-000000A8	R*8							
2-00000128	R*8							
AP-00000004@	R*8							
AP-00000040@	R*8							
AP-0000001C@	R*8							
2-000001A8	R*8							
AP-00000010@	R*8							

4-0000004C R*8 VRO

4-00000018 R*8 XLCPRV

AP-00000014@ R*8 VRI

5-00000020 R*8 XLMBHF

4-00000034 R*8 VTOT

4-00000000 R*8 X

ARRAYS

Address	Type	Name	Bytes	Dimensions
3-00000000	L*4	DEBUG	28	(7)
2-00000000	R*8	P	80	(10)
2-00000050	R*8	VRF	80	(10)

LABELS

Address	Label	Address	Label	Address	Label	Address	Label
**	100	0-000003C5	101	0-0000008C	200	0-000002C9	300
1-0000004E	1002	1-00000039	1003	1-00000073	1004	1-00000000	1000
						1-00000023	1001

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name	Type	Name	Type	Name
ENERNZ		MDRIVE		OUTPUT		PCONTL	
							SENER

```
0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C
0029 C
0030 C
0031 C
0032 C
0033 C
0034 C
0035 C
0036 C
0037 C
0038 C
0039 C
0040 C
0041 C
0042 C
0043 C
0044 C
0045 C
0046 C
0047 C
0048 C
0049 C
0050 C
0051 C
0052 C
0053 C
0054 C
0055 C
0056 C
0057 C

SUBROUTINE MDRIVE (
1  TEMPR, MPBI, UMLII, UMH2OI, MLIOHI, MH2I, VNRI, PI, IPRV,
2  VRI, MINERT,
3  DELTAT,
3  MH2OA, MSTMA, MLMBA, MPBF, UMLIF, UMH2OF, MLIOHF, MH2F,
3  FRPRVA, VNRF, VRF, VGASF, P, ICONTL, SESTMA, SEH2OL )

C This subroutine contains a do loop that drives the reaction
C and nonreaction zones mass balance.

C Since the reaction rate is determined by the interaction of the
C pressure and the inlet and outlet flows, the mass balances, which
C are dependant upon these flows, are the most important balances
C in the overall process. To mirror this, the mass balances are
C carried out 10 times for each time the energy balances are
C calculated.
C
C IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
C IMPLICIT INTEGER ( I-L,N )
C DOUBLE PRECISION P(10), VRF(10), MSTM(10), MH2O(10),
C MLMB(10), FRPRV(10), SESTM(10)
1 LOGICAL DEBUG(7)
COMMON /DEB/ DEBUG, IDBOUT
IF ( DEBUG(2) ) THEN
WRITE ( IDBOUT,1010 )
FORMAT ( ' ENTERING MDRIVE ' )
END IF
DELT = DELTAT * .1
MPBB = MPBI
UMLIB = UMLII
UMH2OB = UMH2OI
MLIOHB = MLIOHI
MH2B = MH2I
VNRB = VNRI
PB = PI
VRB = VRI
DO 100 I = 1,10

C First we determine the flowrate of H2O into the reaction zone.
CALL FLOWRT (
1 PB,
2
3 FRH2O, FRSTM, SESTM(I), SEH2OL )

C Now we calculate the mass balance.
CALL MASS (
1 FRH2O, FRSTM, TEMPR, MPBB, UMLIB, UMH2OB, MLIOHB,
1 MH2B, VNRB, PB, IPRV, VRB, MINERT,
2 DELT,
3 MH2O(I), MSTM(I), MLMB(I), MPBF, UMLIF, UMH2OF, MLIOHF,
3 MH2F, FRPRV(I), VNRF, VRF(I), VGASF, P(I), ICONTL )
IF ( ICONTL.EQ. 1 ) THEN
DELTAT = DELT * 10.
```

```

0058      GO TO 200
0059      END IF
0060      C      This condition checks to see if DELT was adjusted during the
0061      C      execution of MASS. If it has, control is returned to DRIVE.
0062      MPBF = MPBF
0063      UMLIB = UMLIF
0064      UMH2OB = UMH2OF
0065      MLIQHB = MLIQHF
0066      MH2B = MH2F
0067      VNRB = VNRF
0068      PB = P(I)
0069      VRB = VRF(I)
0070      CONTINUE
0071      C
0072      C      Now we must determine the average flowrates over the total
0073      C      timestep.
0074      FRPRVA = 0.
0075      MSTMA = 0.
0076      MH2OA = 0.
0077      MLMBA = 0.
0078      SESTMA = 0.
0079      DO 300 I = 1,10
0080          MSTMA = MSTM(I) + MSTMA
0081          MH2OA = MH2O(I) + MH2OA
0082          MLMBA = MLMB(I) + MLMBA
0083          FRPRVA = FRPRV(I) + FRPRVA
0084          SESTMA = SESTM(I) + SESTMA
0085      300 CONTINUE
0086      SESTMA = SESTMA * .1
0087      C      SESTMA is an average value over the whole timestep. And there-
0088      C      fore must be divided by 10 because it is evaluated over each of
0089      C      the 10 subintervals. The other 4 quantities above are not aver-
0090      C      ages. They are the flow of breeder and water for each of the
0091      C      subintervals, and therefore they must be summed over the whole
0092      C      timestep.
0093      C
0094      C      That's all folks!
0095      IF ( DEBUG(2) ) THEN
0096          WRITE ( IDBOUT,1000)  MH2OA, MSTMA, MLMBA, FRPRVA
0097          FORMAT ( ' MH2OA MSTMA MLMBA FRPRVA ' / 1P4G11.4 )
0098          WRITE ( IDBOUT,1001)  MPBF, UMLIF, UMH2OF, MLIQHF
0099          FORMAT ( ' MPBF UMLIF UMH2OF MLIQHF ' / 1P4G11.4 )
0100          WRITE ( IDBOUT,1002)  MH2F, VNRF, VGASF, SEH2OL
0101          FORMAT ( ' MH2F VNRF VGASF SEH2OL ' / 1P4G11.4 )
0102          WRITE ( IDBOUT,1003)  ( P(I), I = 1,10 )
0103          FORMAT ( ' P ' / 1P4G11.4 / 1P4G11.4 / 1P2G11.4 )
0104          WRITE ( IDBOUT,1004)  ( VRF(I), I = 1,10 )
0105          FORMAT ( ' VRF ' / 1P4G11.4 / 1P4G11.4 / 1P2G11.4 )
0106          WRITE ( IDBOUT,1006)  ( SESTM(I), I=1,10 )
0107          FORMAT ( ' SESTM ' / 1P4G11.4 / 1P4G11.4 / 1P2G11.4 )
0108          WRITE ( IDBOUT,1005)  ( )
0109          FORMAT ( ' EXITING MDRIVE ' )
0110      END IF
0111      CONTINUE
0112      RETURN
0113      END

```

VAX-11 FORTRAN V3.5-62
DUA1:[NUKE.JIM]MARSPRG.;26Total Space Allocated

Address	Type	Name
0-00000000		MDR1

0-00000000 MDRIVE

Address	Type	Name	Address	Type	Name	Address	Type	Name	Address	Type	Name
2-00000190	R#	DELT	AP-00000030@	R#	DELTAT	2-000001D8	R#	FRH20	AP-00000054@	R#	FRPRVA
2-000001E0	R#	FRSTM	2-000001E8	I#4	I	AP-00000068@	I#4	ICONTL	3-0000001C	I#4	IDBOUT
AP-00000024@	I#4	IPRV	2-000001B8	R#	MH2B	AP-00000050@	R#	MH2F	AP-00000018@	R#	MH2I
AP-00000034@	R#	MH20A	AP-0000002C@	R#	MINERT	2-000001B0	R#	MLIOHB	AP-0000004C@	R#	MLIOHF
AP-00000014@	R#	MLIOHI	AP-0000003C@	R#	MLMBA	2-00000198	R#	MPBB	AP-00000040@	R#	MPBF
AP-00000008@	R#	MPBI	AP-00000038@	R#	MSTMA	2-000001C8	R#	PB	AP-00000020@	R#	PI
AP-00000070@	R#	SEH20L	AP-0000006C@	R#	SESTMA	AP-00000004@	R#	TEMPR	2-000001A8	R#	UMH20B
AP-00000048@	R#	UMH20F	AP-00000010@	R#	UMH20I	2-000001A0	R#	UMLIB	AP-00000044@	R#	UMLIF
AP-0000000C@	R#	UMLII	AP-00000060@	R#	VGASF	2-000001C0	R#	VNRB	AP-00000058@	R#	VNRF
AP-0000001C@	R#	VNRI	2-000001D0	R#	VRB	AP-00000028@	R#	VRI			

Address	Type	Name	Bytes	Dimensions
3-00000000	L*4	DEBUG	28	(7)
2-000000F0	R*8	FRPRV	80	(10)
2-00000050	R*8	MH20	80	(10)
2-000000A0	R*8	MLMB	80	(10)
2-00000000	R*8	MSTM	80	(10)
AP-00000064@	R*8	P	80	(10)
2-00000140	R*8	SESTM	80	(10)
AP-0000005C@	R*8	VRF	80	(10)

Address	Label	Address	Label	Address	Label	Address	Label
**	100	0-0000030A	200	**	300	1-00000018	1000'
-000000085	1003,	1-0000000A3	1004,	1-0000000E5	1005,	1-0000000C3	1006,
						1-0000000D	1001'
						1-000000000	1010,
						1-000000062	1002,

MDRIVE

18-JUL-1984 00:20:42
18-JUL-1984 00:19:51

VAX-11 FORTRAN V3.5-62
DUA1:[NUKE.JIM]MARSPRG.;26

Page 23

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name
	FLOWRT		MASS

```
0001 C
0002 C
0003 C *****
0004 C *****
0005 C *****
0006 C *****
0007 C *****
0008 C *****
0009 C *****
0010 C *****
0011 C *****
0012 C *****
0013 C *****
0014 C *****
0015 C *****
0016 C *****
0017 C *****
0018 C *****
0019 C *****
0020 C *****
0021 C *****
0022 C *****
0023 C *****
0024 C *****
0025 C *****
0026 C *****
0027 C *****
0028 C *****
0029 C *****
0030 C *****
0031 C *****
0032 C *****
0033 C *****
0034 C *****
0035 C *****
0036 C *****
0037 C *****
0038 C *****
0039 C *****
0040 C *****
0041 C *****
0042 C *****
0043 C *****
0044 C *****
0045 C *****
0046 C *****
0047 C *****
0048 C *****
0049 C *****
0050 C *****
0051 C *****
0052 C *****
0053 C *****
0054 C *****
0055 C *****
0056 C *****
0057 C *****

      SUBROUTINE FLOWRT (
1 P,
2
3 FRH20, FRSTM, SESTM, SEH20L )
C
C This subroutine calculates the flowrate of all the H2O and the
C steam from the broken tube(s) by the homogeneous equilibrium model.
C FRH20 and FRSTM are evaluated as functions of pressure. These
C flows are from two separate flow paths, one path connected
C to the upper plenum and one to the lower plenum. The H2O from
C the upper plenum is superheated over the whole range of pressures,
C with the critical pressure at 8.9976D6 Pa. The H2O from the lower
C plenum is subcooled. This subroutine also determines the specific
C internal energy of the steam and liquid ( SESTM and SEH20L ).
C
      IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
      IMPLICIT INTEGER ( I-L,N )
      COMMON /INPUT/
1 X, APRV,
2 PPRV, XLCPRV,
3 DELTAI, TIMEND, NPIPES, VTOT,
4 TEPS, PEPS, VRO
C
      IF ( P .LE. 7.54533D6 ) THEN
        FRSTM = 1.947
        FRH20 = 11.064
      ELSE IF ( ( P .LE. 8.2736D6 ) .AND. ( P .GT. 7.54533D6 ) ) THEN
        FRSTM = 1.947
        FRH20 = -5.91814D-7 * P + 15.5294
      ELSE IF ( ( P .LE. 8.9976D6 ) .AND. ( P .GT. 8.2736D6 ) ) THEN
        FRSTM = 1.947
        FRH20 = -6.326D-7 * P + 15.8669
      ELSE IF ( ( P .LE. 9.6526D6 ) .AND. ( P .GT. 8.9976D6 ) ) THEN
        FRH20 = -6.2305D-7 * P + 15.781
        FRSTM = -6.56489D-9 * P + 2.00607
      ELSE IF ( ( P .LE. 1.0342D7 ) .AND. ( P .GT. 9.6526D6 ) ) THEN
        FRSTM = -3.04613D-8 * P + 2.23673
        FRH20 = -7.67044D-7 * P + 17.1709
      ELSE IF ( ( P .LE. 1.1032D7 ) .AND. ( P .GT. 1.0342D7 ) ) THEN
        FRSTM = -5.82609D-8 * P + 2.52423
        FRH20 = -6.85942D-7 * P + 16.3321
      ELSE IF ( ( P .LE. 1.1721D7 ) .AND. ( P .GT. 1.1032D7 ) ) THEN
        FRSTM = -7.73585D-8 * P + 2.73492
        FRH20 = -9.00871D-7 * P + 18.7032
      ELSE IF ( ( P .LE. 1.241D7 ) .AND. ( P .GT. 1.1721D7 ) ) THEN
        FRSTM = -1.16691D-7 * P + 3.19593
        FRH20 = -8.22642D-7 * P + 17.7863
      ELSE IF ( ( P .LE. 1.31D7 ) .AND. ( P .GT. 1.241D7 ) ) THEN
        FRSTM = -1.45073D-7 * P + 3.54815
        FRH20 = -8.69565D-7 * P + 18.3686
      ELSE IF ( ( P .LE. 1.3789D7 ) .AND. ( P .GT. 1.31D7 ) ) THEN
        FRSTM = -1.89695D-7 * P + 4.13271
        FRH20 = -1.02496D-6 * P + 20.4043
```

```

0058 ELSE IF (( P .LE. 1.4479D7 ) .AND. ( P .GT. 1.3789D7 )) THEN
0059   FRSTM = -2.33623D-7 * P + 4.73843
0060   FRH20 = -1.14391D-6 * P + 22.0445
0061 ELSE IF (( P .LE. 1.5168D7 ) .AND. ( P .GT. 1.4479D7 )) THEN
0062   FRSTM = -3.2656D-7 * P + 6.08407
0063   FRH20 = -1.43585D-6 * P + 26.2715
0064 ELSE IF (( P .LE. 1.5858D7 ) .AND. ( P .GT. 1.5168D7 )) THEN
0065   FRSTM = -4.50783D-7 * P + 7.96827
0066   FRH20 = -1.81478D-6 * P + 32.0191
0067 ELSE IF (( P .LE. 1.6547D7 ) .AND. ( P .GT. 1.5858D7 )) THEN
0068   FRSTM = -1.18978D-6 * P + 19.6873
0069   FRH20 = -4.7029D-6 * P + 77.8189
0070 ELSE
0071   FRH20 = 0.
0072   FRSTM = 0.
0073 END IF
0074 C Now the total flowrates are determined by multiplying FRH20
0075 C and FRSTM by the number of broken pipes.
0076   FRH20 = FRH20 * NPIPES
0077   FRSTM = FRSTM * NPIPES
0078 C
0079 C Now to determine the specific energy of the H2O as it leaves
0080 C the break and enters the reaction zone. The energy for the steam
0081 C has been curve fitted to a parabolic form, with the independent
0082 C variable being the pressure at the break. If the system pressure
0083 C is less than the critical pressure (8.9976D6 Pa ), then the
0084 C energy of the steam is determined at the critical pressure.
0085 C The specific energy is determined from the 1st law as:
0086 C  $U = I_b - P * V - 1 / 2 * (VEL)^2 + XH20HF$ 
0087 C where, U is the specific energy, Ib is the back enthalpy,
0088 C P * V is the pressure at the break times the specific volume
0089 C at the break, 1/2 * (VEL)2 is the kinetic energy of
0090 C the water with VEL as the water velocity at the break, and
0091 C XH20HF is the heat of formation of the water. For the subcooled
0092 C water from the lower plenum, the second and third terms of the
0093 C above equation are negligible. Therefore SEH20L is not a function
0094 C of the break pressure.
0095   XH20HF = -2.4185D5
0096   IF ( P .LE. 8.9976D6 ) THEN
0097     PBREAK = 8.9976D6
0098   ELSE
0099     PBREAK = P
0100   END IF
0101   SESTM = 4.6404165D4 + 5.853535D-4 * PBREAK - 1.0704336D-11
0102   * ( PBREAK ** 2. ) + XH20HF
0103 C
0104   SEH20L = 2.315D4 + XH20HF
0105 C
0106 C That's all folks!
0107   RETURN
0108   END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	1237	PIC CON REL LCL SHR EXE RD NOWRT LONG
2 \$LOCAL	16	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
3 INPUT	84	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	1337	

ENTRY POINTS

Address	Type	Name
0-00000000		FLOWRT

VARIABLES

Address	Type	Name	Address	Type	Name
3-00000008	R*8	APRV	AP-0000000C@	R*8	FRSTM
3-00000030	I*4	NPIPES	3-00000044	R*8	PEPS
3-00000010	R*8	PPRV	3-0000003C	R*8	TEPS
3-00000028	R*8	TIMEND	3-00000000	R*8	X
2-00000000	R*8	XH2OHF			
3-00000020	R*8	DELTAI			
AP-00000004@	R*8	P	AP-00000008@	R*8	FRH2O
AP-00000014@	R*8	SEH2OL	2-00000008	R*8	PBREAK
3-00000004C	R*8	VRO	AP-00000010@	R*8	SESTM
3-00000018	R*8	XLCPRV	3-00000034	R*8	VTOT

```
0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C SUBROUTINE MASS (
0008 C 1 FRH2O, FRSTM, TEMPR, MPBI, UMLII, UMH2OI, MLIOHI, MH2I,
0009 C 1 VNRI, PI, IPRV, VRI, MINERT,
0010 C 2 DELTAT,
0011 C 3 MH2O, MSTM, MLMB, MPBF, UMLIF, UMH2OF, MLIOHF, MH2F,
0012 C 3 FRPRV, VNRFF, VRF, VGASF, P, ICONTL )
0013 C
0014 C This subroutine evaluates the end of timestep masses of the
0015 C reaction products in the two zones, given the initial masses of
0016 C the constituents of the zones and the inlet flowrate of water.
0017 C On the basis of the end of timestep reaction zone composition
0018 C and the beginning of timestep pressure, the volumes of the
0019 C reaction and nonreaction zones and the flowrate out of the
0020 C pressure relief valve are determined.
0021 C IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
0022 C IMPLICIT INTEGER ( I-L,N )
0023 C LOGICAL DEBUG(7)
0024 C COMMON /DEB/ DEBUG, IDBOUT
0025 C COMMON /INPUT/
0026 C 1 X, APRV,
0027 C 2 PPRV, XLCPRV,
0028 C 3 DELTAI, TIMEND, NPIPES, VTOT,
0029 C 4 TEPS, PEPS, VRO
0030 C COMMON /PROP/
0031 C 1 DLMB, DLIOH, DLI, DPB,
0032 C 2 XLMBHF,
0033 C 3 TCLMB, TDLMB,
0034 C 4 APLI
0035 C IF ( DEBUG(3) ) THEN
0036 C WRITE ( IDBOUT,1000 )
0037 C FORMAT ( ' ENTERING MASS ' )
0038 C
0039 C REACTION ZONE MASS BALANCE :
0040 C
0041 C First, from a mass balance on the reaction zone we can
0042 C determine the molar composition of the reaction zone at the
0043 C end of the timestep.
0044 C MH2OL = 55.5 * FRH2O * DELTAT
0045 C MSTM = 55.5 * FRSTM * DELTAT
0046 C MH2O = MH2OL + MSTM
0047 C MLI = MH2O / X
0048 C MLMB = MLI / APLI
0049 C MPBF = ( 1. - APLI ) * MLMB + MPBI
0050 C IF ( X .LE. 1. ) THEN
0051 C UMLIF = MLI - MH2O + UMLII
0052 C UMH2OF = 0.
0053 C MLIOHF = MH2O + MLIOHI
0054 C MH2F = 2. * MH2O + MH2I
0055 C ELSE
0056 C UMLIF = 0.
0057 C UMH2OF = MH2O - MLI + UMH2OI
```

```

0058      MLIOHF = MLI + MLIOHI
0059      MH2F = 2. * MLI + MH2I
0060      END IF
0061
0062      C
0063      C
0064      C
0065      C
0066      C
0067      C
0068      C
0069      C
0070      C
0071      C
0072      C
0073      C
0074      C
0075      C
0076      C
0077      C
0078      C
0079      C
0080      C
0081      C
0082      C
0083      C
0084      C
0085      C
0086      C
0087      C
0088      C
0089      C
0090      C
0091      C
0092      C
0093      C
0094      C
0095      C
0096      C
0097      C
0098      C
0099      C
0100      C
0101      C
0102      C
0103      C
0104      C
0105      C
0106      C
0107      C
0108      C
0109      C
0110      C
0111      C
0112      C
0113      C
0114      C

      MLIOHF = MLI + MLIOHI
      MH2F = 2. * MLI + MH2I
      END IF

      NONREACTION ZONE MASS BALANCE :

      From a mass balance on the nonreaction zone, the time rate
      of change of the nonreaction zone mass is found to be due to
      the flow of breeder into the reaction zone and the flow of
      breeder out of the pressure relief valve.

      The flow of breeder into the reaction zone during the
      timestep is simply MLMB.
      MASLMB = ( ( 1 - APLI ) * .20721 + APLI * 6.94D-3 ) * MLMB

      The flow of breeder out of the pressure relief valve is
      determined from Bernoulli's equation. When the pressure first
      becomes greater than PPRV, the rupture disk opens. The condition
      of the rupture disk is set by IPRV, 0 = intact disk, 1 =
      ruptured disk. IPRV is not set to 1 during execution of this
      subroutine, since
      C MASS maybe iterated upon many times during the execution of
      C DRIVE and MDRIVE.
      FRPRV = 0.
      IF ( IPRV.EQ. 1 ) GO TO 100
      IF ( PI.GT. PPRV ) THEN
100      CONTINUE
      IF ( PI.LT. 1.0135D5 ) GO TO 300
      FRPRV = APRV * DSQRT ( 2. * DLMB * ( PI - 1.0135D5 ) )
      / XLCPRV )
300      CONTINUE
      END IF

      MASPRV = FRPRV * DELTAT

      REACTION AND NONREACTION ZONE VOLUMES :

      The nonreaction zone volume is simply the initial nonreaction
      zone volume - loss of volume due to the flow of breeder out
      of the zone.
      VNRF = VNRI - ( MASPRV + MASLMB ) / DLMB

      The volume of the reaction zone is the total breeder volume
      - the nonreaction zone volume.
      VRF = VRI + ( MASPRV + MASLMB ) / DLMB

      We can now determine the volume of the gas ( H2 and H2Og )
      in the reaction zone.
      VGASF = VRF - 6.94D-3 * UMLIF / DLI - 2.31D-2 * MLIOHF
      / DLIOH - .20721 * MPBF / DPB

      ISOTHERMAL PRESSURE :
      Now that the end of timestep gas volume and mass has been
      determined, we can determine the end of timestep isothermal
      pressure. That is, the end of timestep pressure is determined
      from the ideal gas law using the beginning of timestep reaction
      zone temperature TRI.

```

```

0115      P = 8.314 * ( MH2F + MINERT + UMH2OF ) * TEMPR / VGASF
0116      IF ( P .GT. 1.6547D7 ) THEN
0117
0118      C      If this condition is true, it means that the shell side
0119      C      pressure has exceeded the water back pressure. This condition
0120      C      is corrected by a call to PCONTL, which decreases the timestep.
0121      CALL PCONTL (
0122      1 PI, P,
0123      2 DELTAT
0124      3 )
0125      ICONTL = 1
0126      GO TO 200
0127
0128      C      This variable alerts the calling routines MDRIVE and DRIVE
0129      C      that DELTAT has been adjusted.
0130      ELSE
0131      ICONTL = 0
0132      END IF
0133
0134      C      That's all folks!
0135      IF ( DEBUG(3) ) THEN
0136      WRITE ( IDBOUT,1001 ) MH2O, MSTM, MLMB, FRPRV
0137      FORMAT ( ' MH2O MSTM MLMB FRPRV ' / 1P4G11.4 )
0138      WRITE ( IDBOUT,1002 ) MPBF, UMLIF, UMH2OF, MLIOHF, MH2F
0139      FORMAT ( ' MPBF UMLIF UMH2OF MLIOHF MH2F ' / 1P5G11.4 )
0140      WRITE ( IDBOUT,1003 ) VNR, VRF, VGASF, P
0141      FORMAT ( ' VNR VRF VGASF P ' / 1P4G11.4 )
0142      WRITE ( IDBOUT,1004 )
0143      FORMAT ( ' EXITING MASS ' )
0144      END IF
0145
0146      C
0147      200 CONTINUE
0148      RETURN
0149      END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	739	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	139	PIC CON REL LCL SHR NOEXE RD NOWRT LONG
2 \$LOCAL	48	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
3 DEB	32	PIC OVR REL GBL SHR NOEXE RD WRT LONG
4 INPUT	84	PIC OVR REL GBL SHR NOEXE RD WRT LONG
5 PROP	64	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	1106	

ENTRY POINTS

Address	Type	Name
0-00000000		MASS

VARIABLES

Address	Type	Name	Address	Type	Name
5-00000038	R*8	APLI	4-00000008	R*8	APRV
5-00000010	R*8	DLI	5-00000008	R*8	DLIOH
AP-00000004@	R*8	FRH20	AP-0000005C@	R*8	FRPRV
3-0000001C	I*4	IDBOUT	AP-0000002C@	I*4	IPRV
AP-00000058@	R*8	MH2F	AP-00000020@	R*8	MH2I
AP-00000034@	R*8	MINERT	2-00000008	R*8	MLI
AP-00000044@	R*8	MLMB	AP-00000048@	R*8	MPBF
4-00000030	I*4	NPIPES	AP-0000006C@	R*8	P
4-00000010	R*8	PPRV	5-00000028	R*8	TCLMB
4-0000003C	R*8	TEPS	4-00000028	R*8	TIMEND
AP-0000004C@	R*8	UMLIF	AP-00000014@	R*8	UMLII
AP-00000024@	R*8	VNRI	4-0000004C	R*8	VRO
4-00000034	R*8	VTOT	4-00000000	R*8	X
AP-00000038@	R*8	DELTAI	4-00000020	R*8	DLMB
5-00000018	R*8	DPB	5-00000000	R*8	FRSTM
AP-00000070@	I*4	ICONTL	2-00000010	R*8	MASLMB
2-00000018	R*8	MASPRV	AP-0000003C@	R*8	MH20
2-00000000	R*8	MH20L	AP-00000054@	R*8	MLIOHF
AP-0000001C@	R*8	MLIOHI	AP-00000010@	R*8	MPBI
AP-00000040@	R*8	MSTM	4-00000044	R*8	PEPS
AP-00000028@	R*8	PI	5-00000030	R*8	TDLMB
AP-0000000C@	R*8	TEMPR	AP-00000050@	R*8	UMH20F
AP-00000018@	R*8	UMH20I	AP-00000068@	R*8	VGASF
AP-00000060@	R*8	VNRF	AP-00000064@	R*8	VRF
AP-00000030@	R*8	VRI	4-00000018	R*8	XLCPRV
5-00000020	R*8	XLMBHF			

ARRAYS

Address	Type	Name	Bytes	Dimensions
3-00000000	L*4	DEBUG	28	(7)

LABELS

Address	Label	Address	Label	Address	Label
0-00000105	100	0-000002E2	200	1-00000012	1001'
1-0000005D	1003'	1-0000007A	1004'	1-00000000	1000'
				1-00000000	1002'

MASS

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name
R*8	MTH\$DSQRT		PCONTL

18-JUL-1984 00:20:42
18-JUL-1984 00:19:51

VAX-11 FORTRAN V3.5-62
DUA1:[NUKE.JIM]MARSPRG.;26

```

0001 C
0002 C
0003 C*****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C

      SUBROUTINE PCONTL (
1      PI, PF,
2      DELTAT
3      )

C      This subroutine decreases the timestep in order to lower the
C      pressure increase during the timestep.
C      IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
C      IMPLICIT INTEGER ( I-L,N )
C      LOGICAL DEBUG(7)
C      COMMON /DEB/ DEBUG, IDBOUT

C      IF ( DEBUG(6) ) WRITE ( IDBOUT,1000 ) DELTAT
C      DELTAT = DELTAT * PI / PF

C      IF ( DEBUG(6) ) WRITE ( IDBOUT,1001 ) DELTAT
1000      FORMAT ( '***** THE ORIGINAL DELTAT = ', 1P1G11.4 )
1001      FORMAT ( ' IS NOW = ', 1P1G11.4 )

C      That's all folks!
      RETURN
      END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	101	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	82	PIC CON REL LCL SHR NOEXE RD NOWRT LONG
3 DEB	32	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	215	

ENTRY POINTS

Address	Type	Name
0-00000000		PCONTL

VARIABLES

Address	Type	Name	Address	Type	Name
AP-0000000C@ R*8	DELTAT		3-0000001C	I*4	IDBOUT
			AP-00000008@ R*8	PF	
			AP-00000004@ R*8	PI	

ARRAYS

Address	Type	Name	Bytes	Dimensions
3-00000000	L*4	DEBUG	28	(7)

LABELS

Address	Label	Address	Label
1-00000000	1000'	1-00000029	1001'

```

0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C
0029 C
0030 C
0031 C
0032 C
0033 C
0034 C
0035 C
0036 C
0037 C
0038 C
0039 C
0040 C
0041 C
0042 C
0043 C
0044 C
0045 C
0046 C
0047 C
0048 C
0049 C
0050 C
0051 C
0052 C
0053 C
0054 C
0055 C
0056 C
0057 C

SUBROUTINE ENERRZ (
1 TEMPRI, TEMPNI, DELTAT, PI, P, VRF, MPBI, UMLII,
1 UMH2OI, MLIOHI, MH2OI, MH2O, MSTM, MLMB, MPBF, UMLIF, UMH2OF,
1 MLIOHF, MH2F, VRI, URZI, SESTM, SEH2OL,
2
3 QCOND, PVDOT, URZF, ENGIN, QFCRZ, TEMPRF, DRDT )

C This subroutine solves an energy balance on the reaction
C zone. The reaction zone end of timestep energy is determined
C by the change in energy during the timestep. The end of timestep
C average reaction zone temperature is then determined.
C IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
C IMPLICIT INTEGER ( I-L,N )
C DOUBLE PRECISION P(10), VRF(10), PV(10)
C LOGICAL DEBUG(7)
C COMMON /DEB/ DEBUG, IDBOUT
C COMMON /INPUT/
1 X, APRV,
2 PPRV, XLCPRV,
3 DELTAI, TIMEND, NPIPES, VTOT,
4 TEPS, PEPS, VRO
C COMMON /PROP/
1 DLMB, DLIOH, DLI, DPB,
2 XLMBHF,
3 TCLMB, TDLMB,
4 APLI
C IF ( DEBUG(4) ) THEN
WRITE ( IDBOUT,1000 )
FORMAT ( ' ENTERING ENERRZ ' )
1000 END IF

C The energy balance can be expressed as:
C URZF = URZI + DELTAT* ( -PVDOT - QCOND + ENGIN - QFCRZ )

C ***** QFCRZ *****
C This is the change in reaction zone energy due to forced
C convection to unbroken steam tubes. This quantity is very
C approximate. So we assume it is not a function of TEMPRF
C for simplicity.
C QFCRZ = 1.36D5 * ( VRF(10) + VRI ) * ( TEMPRI - 648. )

C ***** PVDOT *****
C This is the energy change due to the work the fluid in the
C reaction zone does as it expands. There are 10 parts to this
C quantity for each of the 10 subtimesteps.
C DELT = DELTAT * .1
C PV(1) = .5 * ( P(1) + PI ) * ( VRF(1) - VRI ) / DELT
C DO 100 I = 2,10
C PV(I) = .5 * ( P(I) + P(I-1) ) * ( VRF(I) - VRF(I-1) )
100 CONTINUE

```

```

0058 C          PVDOT = 0.
0059 DO 200 J = 1,10
0060     PVDOT = PVDOT + PV(J)
0061 CONTINUE
0062     PVDOT = PVDOT * .1
0063
0064 C ***** ENGIN *****
0065 C This is the energy of the H2O and the breeder flowing into
0066 C the reaction zone during the timestep.
0067     PAVE = ( PI + P(10) ) * .5
0068
0069 C
0070 CALL SENER (
0071     1 TEMPNI, PAVE,
0072     2
0073     3 SEH2, SELIOH, SEH20, SEPB, SELI,
0074     4 DSEH2, DSLIOH, DSEH20, DSEPB, DSELI )
0075
0076 C The temperature at which the liquid metal breeder internal
0077 C energy is determined at is the temperature of the nonreaction
0078 C zone, since this is the origin of the LMB.
0079     ENGIN = ( MSTM * SESTM + ( MH20 - MSTM ) * SEH20L +
0080     1 MLMB * ( ( 1 - APLI ) * SEPB + APLI * SELI +
0081     2 XLMBHF ) ) / DELTAT
0082
0083 C ***** URZI *****
0084 C This is the internal energy of the reaction zone contents
0085 C at the beginning of the timestep. It is equal to the final
0086 C internal energy of the reaction zone from the last timestep.
0087 C
0088 C Now we are ready for the temperature iteration loop.
0089     TEMP = TEMPRI
0090 CONTINUE
0091
0092 C ***** QCOND *****
0093 C This is the heat transferred from the reaction zone to the
0094 C nonreaction zone due to conduction. It is a function of the
0095 C reaction zone final temperature.
0096     RADRF = .62 * ( VRF(10) ** ( 1. / 3. ) )
0097     RADZI = .62 * ( VRI ** ( 1. / 3. ) )
0098     RADAVG = .75 * ( RADRF ** 4. - RADZI ** 4. ) /
0099     1 ( RADRF ** 3. - RADZI ** 3. )
0100
0101     DRDT = ( RADRF - RADZI ) / DELTAT
0102
0103     PEND = 1.77 * DSQRT ( DELTAT * TDLMB )
0104
0105 C
0106     QCOND = 6.23 * TCLMB * ( TEMP + TEMPRI - 2. * TEMPNI )
0107     * ( RADAVG ** 2. ) / PEND
0108
0109 C ***** URZF *****
0110 C We now sum up the energy flows to determine the end of
0111 C timestep reaction zone internal energy.
0112     URZF = URZI + DELTAT * ( ENGIN - QFCRZ - PVDOT - QCOND )
0113
0114 C ***** TEMPRF *****

```

ENERRZ

```

0115 C We now determine the end of timestep temperature of the
0116 C reaction zone from the value of URZF.
0117 CALL ROOT (
0118 1 TEMPRI, URZF, PAVE,
0119 1 MPBF, UMLIF, UMH2OF, MLIOHF, MH2F,
0120 2
0121 3 TEMPRF )
0122 C
0123 IF ( ( DABS ( TEMPRF - TEMP ) ) .GT. TEPS ) THEN
0124 C If this condition is true it means that the temperature used
0125 C to calculate QCOND is not the end of timestep temperature.
0126 C Thus we must iterate until this condition is false.
0127 TEMP = TEMPRF
0128 GO TO 300
0129 END IF
0130 C
0131 C That's all folks!
0132 IF ( DEBUG(4) ) THEN
0133 WRITE ( IDBOUT,1001 ) URZI, QCOND, PVDOT
0134 FORMAT ( ' URZI QCOND PVDOT ' / 1P3G11.4 )
0135 WRITE ( IDBOUT,1002 ) QFCRZ, ENGIN, PEND
0136 FORMAT ( ' QFCRZ ENGIN PEND ' / 1P3G11.4 )
0137 WRITE ( IDBOUT,1003 ) URZF, TEMPRF
0138 FORMAT ( ' URZF TEMPRF ' / 1P2G11.4 )
0139 WRITE ( IDBOUT,1004 )
0140 FORMAT ( ' EXITING ENERRZ ' )
0141 END IF
0142 C
0143 RETURN
0144 END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	872	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	121	PIC CON REL LCL SHR NOEXE RD NOWRT LONG
2 \$LOCAL	372	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
3 DEB	32	PIC OVR REL GBL SHR NOEXE RD WRT LONG
4 INPUT	84	PIC OVR REL GBL SHR NOEXE RD WRT LONG
5 PROP	64	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	1545	

ENTRY POINTS

Address	Type	Name
0-00000000		ENERRZ

VARIABLES

Address	Type	Name	Address	Type	Name
5-00000038	R*8	APLI	4-00000008	R*8	APRV
AP-0000000C@	R*8	DELTAT	5-00000010	R*8	DLI
5-00000018	R*8	DPB	AP-00000078@	R*8	DRDT
2-0000000A8	R*8	DSELI	2-0000000A0	R*8	DSEPB
2-0000000D8	I*4	I	3-0000001C	I*4	IDBOUT
AP-00000002C@	R*8	MH2I	AP-000000030@	R*8	MH2O
AP-000000038@	R*8	MLMB	AP-00000003C@	R*8	MPBF
4-00000030	I*4	NPIPES	2-000000058	R*8	PAVE
AP-000000010@	R*8	PI	4-00000010	R*8	PPRV
AP-000000070@	R*8	QFCRZ	2-0000000C8	R*8	RADAVG
2-000000060	R*8	SEH2	2-000000070	R*8	SEH20
2-000000068	R*8	SELI0H	2-000000078	R*8	SEPB
5-000000030	R*8	TDLMB	2-0000000B0	R*8	TEMP
AP-000000004@	R*8	TEMPRI	4-00000003C	R*8	TEPS
AP-000000024@	R*8	UMH2OI	AP-000000040@	R*8	UMLIF
AP-000000054@	R*8	URZI	4-00000004C	R*8	VRO
4-000000000	R*8	X	4-000000018	R*8	XLCPRV
			2-000000050	R*8	DELT
			5-000000008	R*8	DLIOH
			2-000000088	R*8	DSEH2
			2-000000090	R*8	DSLIOH
			2-0000000DC	I*4	J
			AP-000000048@	R*8	MLIOHF
			AP-00000001C@	R*8	MPBI
			2-0000000D0	R*8	PEND
			AP-000000064@	R*8	PVDOT
			2-0000000B8	R*8	RADRZF
			AP-00000005C@	R*8	SEH2OL
			AP-000000058@	R*8	SESTM
			AP-000000008@	R*8	TEMPNI
			4-000000028	R*8	TIMEND
			AP-000000020@	R*8	UMLII
			AP-000000050@	R*8	VRI
			5-000000020	R*8	XLMBHF
			4-000000020	R*8	DELTAI
			5-000000000	R*8	DLMB
			2-000000098	R*8	DSEH2O
			AP-00000006C@	R*8	ENGIN
			AP-00000004C@	R*8	MH2F
			AP-000000028@	R*8	MLIOHI
			AP-000000034@	R*8	MSTM
			4-000000044	R*8	PEPS
			AP-000000060@	R*8	QCOND
			2-0000000C0	R*8	RADRZI
			2-000000080	R*8	SELI
			5-000000028	R*8	TCLMB
			AP-000000074@	R*8	TEMPRF
			AP-000000044@	R*8	UMH2OF
			AP-000000068@	R*8	URZF
			4-000000034	R*8	VTOT

ARRAYS

Address	Type	Name	Bytes	Dimensions
3-000000000	L*4	DEBUG	28	(7)
AP-000000014@	R*8	P	80	(10)
2-000000000	R*8	PV	80	(10)
AP-000000018@	R*8	VRF	80	(10)

LABELS

Address	Label	Address	Label	Address	Label	Address	Label	Address	Label
**	100	**	200	0-0000013D	300	1-00000000	1000'	1-00000014	1001'
1-00000004E	1003'	1-000000066	1004'					1-000000031	1002'

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name
R*8	MTH\$DSORT		
			SENER

```

0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C
0029 C
0030 C
0031 C
0032 C
0033 C
0034 C
0035 C
0036 C
0037 C
0038 C
0039 C
0040 C
0041 C
0042 C
0043 C
0044 C
0045 C
0046 C
0047 C
0048 C
0049 C
0050 C
0051 C
0052 C
0053 C
0054 C
0055 C
0056 C
0057 C

      SUBROUTINE SENER (
1    T, P,
2
3    SEH2, SELIOH, SEH2O, SEPB, SELI,
4    DSEH2, DSLIOH, DSEH2O, DSEPB, DSELI )

      This subroutine calculates the specific energy and the
      temperature derivative of the specific energy for H2, LIOH,
      H2O, PB, and LI, as functions of the input temperature (T).

      The constants used in the subroutine are taken from the
      JANAF tables. The reference temperature is 273.15 K.

      IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
      IMPLICIT INTEGER ( I-L,N )

      ***** H2 *****
      The specific heat at constant volume for an ideal diatomic
      gas is 5/2* ideal gas constant.
      SEH2 = 20.75 * ( T - 273.15 )
      DSEH2 = 20.75

      ***** LIOH *****
      LIOH changes phase (melts) at 744.3 K. For T .LE. 744.3
      the specific energy is curve fitted so that the specific energy
      and the temperature derivative of the specific energy are
      continuous at T=744.3 K. The specific energy includes the
      heat of formation (4.7388D5 J/MOLE ).
      IF ( T .GE. 744.3 ) THEN
        SELIOH = 86.78 * ( T - 744.3 ) - 4.243D5
        DSLIOH = 86.78
      ELSE
        SELIOH = -3.931D-2 * ( ( T - 273.15 ) ** 2. ) +
          123.8 * ( T - 273.15 ) - 4.739D5
        DSLIOH = -7.862D-2 * ( T - 273.15 ) + 123.8
      END IF

      ***** H2O *****
      The water is assumed to be superheated steam. The specific
      heat at constant volume is assumed to be 27. J/MOLE over the
      range of pressure and temperature. The specific energy is
      equal to :
      27. * ( T - TVAP ) + HVAP + XH2OHF
      where: TVAP is the vaporation temperature, HVAP is the
      saturated steam enthalpy and XH2OHF is the water heat of formation.
      TVAP and HVAP are functions of pressure, the equations for which
      were determined by curve fitting data between pressures of
      1.724D5 and 1.6547D7 Pa.
      IF ( P .EQ. 0. ) THEN
        P will equal 0 when the nonreaction zone energy is being
        determined. Since the nonreaction zone does not contain any
        water the specific energy of the water in that case need not
        be determined.

```

```

SENER
      C
0058      SEH20 = 0.
0059      DSEH20 = 0.
0060      ELSE
0061      XH20HF = -2.418D5
0062      TVAP = 308.84026 * DEXP ( ( DLOG( P ) - 5.9053292 )
0063      ** 2. / 163.65165 )
0064      HVAP = 5.0249453D4 * DEXP ( -1. * ( ( P - 4.5033433D6 )
0065      ** 2. / 1.6713273D15 ) )
0066      SEH20 = 27. * ( T - TVAP ) + HVAP + XH20HF
0067      DSEH20 = 27.
0068      END IF
0069
0070      C
0071      C *****
0072      C We assume that T .GT. Tmelt = 600.6 K.
0073      SEPB = 30.3 * ( T - 600.6 ) + 1.394D4
0074      DSEPB = 30.3
0075      C
0076      C *****
0077      C We assume that T .GT. Tmelt = 453.7 K.
0078      SELI = 29.7 * ( T - 453.7 ) + 7.85D3
0079      DSELI = 29.7
0080      C
0081      RETURN
0082      END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	469	PIC CON REL LCL SHR EXE RD NOWRT LONG
2 \$LOCAL	24	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
Total Space Allocated	493	

ENTRY POINTS

Address	Type	Name
0-00000000		SENER

VARIABLES

Address	Type	Name	Address	Type	Name
AP-00000020@ R*8		DSEH2	AP-00000030@ R*8		DSELI
AP-00000024@ R*8		DSLIOH	AP-00000008@ R*8		P
AP-00000014@ R*8		SEH20	AP-00000010@ R*8		SELIOH
AP-00000004@ R*8		T	2-00000000 R*8		XH20HF
			AP-0000002C@ R*8		DSEPB
			AP-0000000C@ R*8		SEH2
			AP-00000018@ R*8		SEPB

SENER

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name
R*8	MTH\$DEXP	R*8	MTH\$DLOG

18-Jul-1984 00:20:42
18-Jul-1984 00:19:51

VAX-11 FORTRAN V3.5-62
DUA1:[NUKE.JIM]MARS PRG.;26

```

0001 C
0002 C *****
0003 C *****
0004 C *****
0005 C *****
0006 C *****
0007 C *****
0008 C *****
0009 C *****
0010 C *****
0011 C *****
0012 C *****
0013 C *****
0014 C *****
0015 C *****
0016 C *****
0017 C *****
0018 C *****
0019 C *****
0020 C *****
0021 C *****
0022 C *****
0023 C *****
0024 C *****
0025 C *****
0026 C *****
0027 C *****
0028 C *****
0029 C *****
0030 C *****
0031 C *****
0032 C *****
0033 C *****
0034 C *****
0035 C *****
0036 C *****
0037 C *****
0038 C *****
0039 C *****
0040 C *****
0041 C *****
0042 C *****
0043 C *****
0044 C *****
0045 C *****
0046 C *****
0047 C *****
0048 C *****
0049 C *****
0050 C *****
0051 C *****
0052 C *****
0053 C *****
0054 C *****
0055 C *****
0056 C *****
0057 C *****

SUBROUTINE ROOT (
1  TI, UF, P,
1  MPBF, UMLIF, UMH2OF, MLIOHF, MH2F,
2
3  TF )

C This subroutine determines the end of timestep temperature by
C Newton's method for finding the roots of an equation.
C IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
C IMPLICIT INTEGER ( I-L,N )
C LOGICAL DEBUG (7)
C COMMON /INPUT/
1  X, APRV,
2  PPRV, XLCPRV,
3  DELTAI, TIMEND, NPIPES, VTOT,
4  TEPS, PEPS, VRI
C COMMON /DEB/ DEBUG, IDBOUT
IF ( DEBUG(5) ) THEN
WRITE ( IDBOUT,1000 )
FORMAT ( ' ENTERING ROOT ' )
WRITE ( IDBOUT,1001 ) TI, UF, MPBF, UMLIF
FORMAT ( ' TI UF MPBF UMLIF ' / 1P4G11.4 )
WRITE ( IDBOUT,1002 ) UMH2OF, MLIOHF, MH2F
FORMAT ( ' UMH2OF MLIOHF MH2F ' / 1P3G11.4 )
END IF

C Newton's method for finding roots gives:
TF = TI - F(TI) / ( dF(TI)/dT )

C where,
C F(TI) = UF - ( MPBF*SEPB + UMLIF*SELI + UMH2OF*SEH2 +
MLIOHF*SELIH + MH2F*SEH2F )

C and,
C dF(TI)/dT = MPBF*DSEPB + UMLIF*DSELI + UMH2OF*DSEH2 +
MLIOHF*DSLIOH + MH2F*DSEH2

C TDUM = TI
C CONTINUE

CALL SENER (
1  TDUM, P,
2
3  SEH2, SELIOH, SEH20, SEPB, SELI,
3  DSEH2, DSLIOH, DSEH20, DSEPB, DSELI )

C TF = TDUM + ( UF - ( MH2F * SEH2 + MLIOHF * SELIOH +
UMH2OF * SEH20 + MPBF * SEPB + UMLIF * SELI ) ) /
( MH2F * DSEH2 + MLIOHF * DSLIOH + UMH2OF * DSEH20
+ MPBF * DSEPB + UMLIF * DSELI )

```

```

ROOT
0058 C
0059 IF ( DEBUG(5) ) THEN
0060 WRITE ( IDBOUT,1003 ) TF
0061 FORMAT ( ' ITERATION TF ' / 1P1G11.4 )
0062 END IF
0063 C
0064 C
0065 IF ( ( DABS ( TF - TDUM ) ) .GT. TEPS ) THEN
0066 If this condition is true, then we must reiterate until
0067 C TF - TDUM converges to TEPS .
0068 C
0069 TDUM = TF
0070 GO TO 100
0071 END IF
0072 C
0073 IF ( DEBUG(5) ) THEN
0074 WRITE ( IDBOUT,1004 ) TF
0075 FORMAT ( ' TF ' / 1P1G11.4 )
0076 WRITE ( IDBOUT,1005 )
0077 FORMAT ( ' EXITING ROOT ' )
0078 END IF
0079 C
0080 C That's all folks!
0081 RETURN
0082 END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	412	PIC CON REL LCL
1 \$PDATA	131	PIC CON REL LCL
2 \$LOCAL	140	PIC CON REL LCL
3 INPUT	84	PIC OVR REL GBL
4 DEB	32	PIC OVR REL GBL
Total Space Allocated	799	

ENTRY POINTS

Address	Type	Name
0-00000000		ROOT

VARIABLES

Address	Type	Name	Address	Type	Name
3-00000008	R*8	APRV	2-00000030	R*8	DSEH2
2-00000050	R*8	DSELI	2-00000038	R*8	DSLIOH
AP-00000020@	R*8	MH2F	AP-00000010@	R*8	MPBF
AP-0000000C@	R*8	P	3-00000010	R*8	PPRV
			2-00000040	R*8	DSEH20
			4-0000001C	I*4	IDBOUT
			3-00000030	I*4	NP1PES
			2-00000008	R*8	SEH2

2-00000018	R*8	SEH20	2-00000028	R*8	SELI	2-00000010	R*8	SELIOH	2-00000020	R*8	SEPB
2-00000000	R*8	TDUM	3-0000003C	R*8	TEPS	AP-00000024@	R*8	TF	AP-00000004@	R*8	TI
3-00000028	R*8	TIMEND	AP-00000008@	R*8	UF	AP-00000018@	R*8	UMH20F	AP-00000014@	R*8	UMLIF
3-0000004C	R*8	VRI	3-00000034	R*8	VTOT	3-00000000	R*8	X	3-00000018	R*8	XLCPRV

ARRAYS

Address	Type	Name	Bytes	Dimensions
4-00000000	L*4	DEBUG	28	(7)

LABELS

Address	Label	Address	Label	Address	Label	Address	Label				
0-0000000AB	100	1-00000000	1000'	1-00000012	1001'	1-0000002F	1002'	1-0000004E	1003'	1-00000065	1004'
1-00000072	1005'										

FUNCTIONS AND SUBROUTINES REFERENCED

Type Name

SENER

```

0001 C
0002 C
0003 C *****
0004 C
0005 C
0006 C
0007 C
0008 C
0009 C
0010 C
0011 C
0012 C
0013 C
0014 C
0015 C
0016 C
0017 C
0018 C
0019 C
0020 C
0021 C
0022 C
0023 C
0024 C
0025 C
0026 C
0027 C
0028 C
0029 C
0030 C
0031 C
0032 C
0033 C
0034 C
0035 C
0036 C
0037 C
0038 C
0039 C
0040 C
0041 C
0042 C
0043 C
0044 C
0045 C
0046 C
0047 C
0048 C
0049 C
0050 C
0051 C
0052 C
0053 C
0054 C
0055 C
0056 C
0057 C

SUBROUTINE ENERNZ (
1 VNRI, VNRF, TEMPNI, DELTAT, PVDOT, QCOND, FRPRV, MLMB, UNZI,
2 UNZF, TEMPNF, ENGOUT, QFCNZ )
3

C This subroutine solves an energy balance on the nonreaction
C zone. The nonreaction zone end of timestep energy is determined
C by the change in energy during the timestep. The end of timestep
C average nonreaction zone temperature is then determined.
C
C IMPLICIT DOUBLE PRECISION ( A-H,M,O-Z )
C IMPLICIT INTEGER ( I-L,N )
C LOGICAL DEBUG(7)
C COMMON /DEB/ DEBUG, IDBOUT
C COMMON /INPUT/
C
C 1 X, APRV,
C 2 PPRV, XLCPRV,
C 3 DELTAT, TIMEND, NPIPES, VTOT,
C 4 TEPS, PEPS, VRO
C COMMON /PROP/
C
C 1 DLMB, DLIOH, DLI, DPB,
C 2 XLMBHF,
C 3 TCLMB, TDLMB,
C 4 APLI
C
C IF ( DEBUG(7) ) THEN
C WRITE ( IDBOUT,1000 )
C FORMAT ( ' ENTERING ENERNZ ' )
C
1000 END IF
C
C The energy balance can be expressed as :
C UNZF = UNZI + DELTAT * ( PVDOT + QCOND - ENGOUT - QFCNZ )
C
C ***** QFCNZ *****
C This is the change in the nonreaction zone energy due to
C forced convection to unbroken steam tubes. This function is
C very approximate.
C QFCNZ = 4.305 * ( VNRF + VNRI ) * ( TEMPNI - 648. )
C
C ***** PVDOT *****
C This is just the work due to expansion as calculated in
C ENERRZ, with an opposite sign.
C
C ***** QCOND *****
C This is the heat flow due to conduction as calculated in
C ENERRZ, again with an opposite sign.
C
C ***** ENGOUT *****
C This is the energy of the breeder flowing out of the nonreaction
C zone through the pressure relief valve (FRPRV) and to the reaction
C zone (MLMB).
C P = 0.
C CALL SENER (

```

```

0058 1 TEMPNI, P,
0059 2
0060 3 SEH2, SELIOH, SEH20, SEPB, SELI,
0061 3 DSEH2, DSLIOH, DSEH20, DSEPB, DSELI )
0062 SELMB = ( 1. - APLI ) * SEPB + APLI * SELI + XLMBHF
0063 ENGOUT = ( MLMB / DELTAT + FRPRV / ( 1. - APLI )
0064 1 * .20721 + APLI * 6.94D-3 ) * SELMB
0065
0066 C ***** UNZI *****
0067 C This is the internal energy of the liquid metal breeder
0068 C in the nonreaction zone at the beginning of the timestep.
0069 C It equals the final internal energy of the nonreaction zone
0070 C from the last timestep.
0071 C
0072 C ***** UNZF *****
0073 C We can now sum up the energy changes to determine the end
0074 C of timestep nonreaction zone internal energy.
0075 UNZF = UNZI + DELTAT * ( PVDOT + QCOND - ENGOUT - QFCNZ )
0076 C
0077 C ***** TEMPNF *****
0078 C We can now determine the nonreaction zone end of timestep
0079 C temperature from the value of UNZF.
0080 C
0081 C Before we call ROOT though, we must input the correct list of
0082 C the dummy variables shared with ROOT, so that ROOT performs
0083 C properly.
0084 MH2N = 0.
0085 MLIOHN = 0.
0086 UMH2ON = 0.
0087 MLMBNF = VNRF * DLMB / ( ( 1. - APLI ) * .20721 +
0088 1 APLI * 6.94D-3 )
0089 MPBN = ( 1. - APLI ) * MLMBNF
0090 MLIN = APLI * MLMBNF
0091 C Also, ROOT does not allow for the heat of formation of the
0092 C of the breeder directly, so it must be inputted indirectly.
0093 UNZ = UNZF - MLMBNF * XLMBHF
0094 CALL ROOT (
0095 1 TEMPNI, UNZ, P,
0096 1 MPBN, MLIN, UMH2ON, MLIOHN, MH2N,
0097 2
0098 3 TEMPNF )
0099 C
0100 IF ( DEBUG(7) ) THEN
0101 WRITE ( IDBOUT,1001 ) UNZI, UNZF, TEMPNF
0102 FORMAT ( ' UNZI UNZF TEMPNF ' / 1P3G11.4 )
0103 WRITE ( IDBOUT,1002 ) ENGOUT, QFCNZ
0104 FORMAT ( ' ENGOUT QFCNZ ' / 1P2G11.4 )
0105 WRITE ( IDBOUT,1003 )
0106 FORMAT ( ' EXITING ENERNZ ' )
0107 END IF
0108 C
0109 C That's all folks!
0110 RETURN
0111 END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
U \$CODE	423	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	93	PIC CON REL LCL SHR NOEXE RD NOWRT LONG
2 \$LOCAL	244	PIC CON REL LCL NOSHR NOEXE RD WRT QUAD
3 DEB	32	PIC OVR REL GBL SHR NOEXE RD WRT LONG
4 INPUT	84	PIC OVR REL GBL SHR NOEXE RD WRT LONG
5 PROP	64	PIC OVR REL GBL SHR NOEXE RD WRT LONG
Total Space Allocated	940	

ENTRY POINTS

Address	Type	Name
0-00000000		ENERNZ

VARIABLES

Address	Type	Name	Address	Type	Name
5-00000038	R*8	APLI	4-00000008	R*8	APRV
5-00000010	R*8	DLI	5-00000008	R*8	DLIOH
2-00000030	R*8	DSEH2	2-00000040	R*8	DSEH20
2-00000038	R*8	DSLIOH	AP-00000030@	R*8	ENGOUT
2-00000060	R*8	MHZN	2-00000088	R*8	MLIN
2-00000078	R*8	MLMBNF	2-00000080	R*8	MPBN
4-00000044	R*8	PEPS	4-00000010	R*8	PPRV
AP-00000034@	R*8	QFCNZ	2-00000008	R*8	SEH2
2-00000010	R*8	SELIOH	2-00000058	R*8	SELMB
5-00000030	R*8	TDLMB	AP-0000002C@	R*8	TEMPNF
4-00000028	R*8	TIMEND	2-00000070	R*8	UMH2ON
AP-00000024@	R*8	UNZI	AP-00000008@	R*8	VNRF
4-00000034	R*8	VTOT	4-00000000	R*8	X
AP-00000010@	R*8	DELTAT	4-00000020	R*8	DELTAI
5-00000018	R*8	DPB	5-00000000	R*8	DLMB
2-00000048	R*8	DSEPB	2-00000050	R*8	DSELI
3-0000001C	I*4	IDBOUT	AP-0000001C@	R*8	FRPRV
AP-00000020@	R*8	MLMB	2-00000068	R*8	MLIOHN
2-00000000	R*8	P	4-00000030	I*4	NPIPES
AP-00000018@	R*8	QCOND	AP-00000014@	R*8	PVDOT
2-00000028	R*8	SELI	2-00000018	R*8	SEH20
5-00000028	R*8	TCLMB	2-00000020	R*8	SEPB
4-0000003C	R*8	TEPS	AP-0000000C@	R*8	TEMPNI
AP-00000028@	R*8	UNZF	2-00000090	R*8	UNZ
4-0000004C	R*8	VRO	AP-00000004@	R*8	VNRI
5-00000020	R*8	XLMBHF	4-00000018	R*8	XLCPRV

ARRAYS

Address	Type	Name	Bytes	Dimensions
3-00000000	L*4	DEBUG	28	(7)

LABELS

Address	Label	Address	Label	Address	Label
1-00000000	1000'	1-00000014	1001'	1-00000031	1002'
				1-0000004A	1003'

ENERNZ

18-JUL-1984 00:20:42
18-JUL-1984 00:19:51

VAX-11 FORTRAN V3.5-62
DUA1:[NUKE.JIM]MARSPRG.;26

Page 48

FUNCTIONS AND SUBROUTINES REFERENCED

Type	Name	Type	Name
	ROOT		SENER


```

0058 IF ( PF .GE. PMAX ) PMAX = PF
0059 IF ( TEMPRF .GE. TMAX ) TMAX = TEMPRF
0060
0061 C
0062 C Now we update the list output files.
0063 WRITE ( ITEMP,100 ) TIME, TEMPRF, TEMPNF
0064 FORMAT ( 10X, 1P1G11.4, 10X, 1P1G11.4, 10X, 1P1G11.4 )
0065 WRITE ( IPRES,101 ) TIME, PF
0066 FORMAT ( 10X, 1P1G11.4, 10X, 1P1G11.4 )
0067 WRITE ( IMH2,102 ) TIME, MH2F
0068 FORMAT ( 10X, 1P1G11.4, 10X, 1P1G11.4 )
0069 WRITE ( IFLOW,103 ) TIME, MH2O, FRPRV
0070 FORMAT ( 10X, 1P1G11.4, 10X, 1P1G11.4, 10X, 1P1G11.4 )
0071 C
0072 C Now for the general output file.
0073 C The composition of the general output file is determined by
0074 C the value of the 3 control common variables JOUT1, JOUT2, and
0075 C JOUT3. These variables are set during the execution of INCHNG.
0076 IF ( JOUT1 .NE. 1 ) GO TO 10
0077 C
0078 C First we relate the program variables at the top of the out-
0079 C put file.
0080 IF ( ( NOUT .EQ. 1 ) ) THEN
0081 XAPLI = 100. * APLI
0082 APPB = 100. * ( 1. - APLI )
0083 WRITE ( IOUT,220 ) X, APRV, PPRV, TIMEND, NPIPES, VRO,
0084 XAPLI, APPB
0085
0086 220 FORMAT ( 5X, 'THE PROGRAM VARIABLES ARE :'/
0087 15X, 'THE MIXING PARAMETER -----', 1P1G11.4/
0088 15X, 'PRESSURE RELIEF VALVE AREA - ', 1P1G11.4,
0089 ' M2', /
0090 15X, 'PRV PRESSURE SET POINT -----', 1P1G11.4,
0091 ' N/M2', /
0092 15X, 'CALCULATION END TIME -----', 1P1G11.4,
0093 ' SEC', /
0094 15X, 'NUMBER OF BROKEN STEAM TUBES ', I3 /
0095 15X, 'THE INITIAL REACTION ZONE VOL', 1P1G11.4,
0096 ' M3', / 15X, 'THE BREEDER IS COMPOSED OF ',
0097 1P1G11.4, ' % LI AND ', 1P1G11.4, ' % PB '/
0098 5X / 5X / 5X )
0099 END IF
0100 C
0101 C IF ( NFLAG .EQ. 0 ) THEN
0102 WRITE ( IOUT,200 ) TIME
0103 WRITE ( IOUT,201 ) TEMPRF, TEMPNF, PF, VRF, VGASF
0104 IF ( JOUT2 .EQ. 1 ) WRITE ( IOUT,202 ) MH2OFR, MLMBFR,
0105 MPRVFR, MH2F, MPBF, UMLIF, UMH2OF, MLIOHF, DRDT
0106 IF ( JOUT3 .EQ. 1 ) WRITE ( IOUT,203 ) QCOND, PVDOT,
0107 ENGIN, ENGOUT, QFCRZ, QFCNZ, URZF, UNZF, URZI,
0108 UNZI, SUMQ, SUMU
0109 ELSE
0110 C
0111 WRITE ( IOUT,200 ) TIME
0112 WRITE ( IOUT,201 ) TEMPRF, TEMPNF, PF, VRF, VGASF
0113 IF ( JOUT2 .EQ. 1 ) WRITE ( IOUT,202 ) MH2OFR, MLMBFR,
0114 MPRVFR, MH2F, MPBF, UMLIF, UMH2OF, MLIOHF

```

```

0115      END IF
0116
0117      C 200      FORMAT ( 10X / 10X / '*****',
0118      1 '*****' / 5X, ' END OF TIMESTEP TIME -----',
0119      2 1P1G11.4, ' SEC ' / )
0120
0121      C 201      FORMAT ( 10X / 5X, ' REACTION ZONE TEMPERATURE -- ' ,
0122      1 1P1G11.4, ' K ' /
0123      2 5X, ' NONREACTION ZONE TEMPERATURE ' , 1P1G11.4, ' K ' /
0124      3 5X/5X, ' SYSTEM PRESSURE -----', 1P1G11.4, ' PA ' /
0125      4 5X/5X, ' REACTION ZONE VOLUME -----', 1P1G11.4, ' M3 ' /
0126      5 5X, ' GAS VOLUME -----', 1P1G11.4, ' M3 ' / )
0127
0128      C
0129      C 202      FORMAT ( 5X/5X, ' MOLAR FLOWRATE - H2O -----', 1P1G11.4,
0130      1 ' MOLES/SEC ' /
0131      2 5X, ' MOLAR FLOWRATE TO R.Z. - LMB ' , 1P1G11.4, ' MOLES/SEC ' /
0132      3 5X, ' MOLAR FLOWRATE OUT OF PRV --', 1P1G11.4, ' MOLES/SEC ' /
0133      4 5X/5X, ' MASS OF H2 IN R.Z. -----', 1P1G11.4, ' MOLES ' /
0134      5 5X, ' MASS OF PB IN R.Z. -----', 1P1G11.4, ' MOLES ' /
0135      6 5X, ' MASS OF UNREACTED LI IN R.Z. -----', 1P1G11.4, ' MOLES ' /
0136      7 5X, ' MASS OF UNREACTED H2O IN R.Z. -----', 1P1G11.4, ' MOLES ' /
0137      8 5X, ' MASS OF LIQH IN R.Z. -----', 1P1G11.4, ' MOLES ' /
0138      9 5X/5X, ' R.Z. EXPANSION VELOCITY ----', 1P1G11.4, ' M/SEC' / )
0139
0140      C
0141      C 203      FORMAT ( 5X/5X, ' CONDUCTION ENERGY -----', 1P1G11.4,
0142      1 ' J/SEC ' /
0143      2 5X, ' FLUID EXPANSION WORK -----', 1P1G11.4, ' J/SEC ' /
0144      3 5X, ' ENERGY FLOW INTO R.Z. -----', 1P1G11.4, ' J/SEC ' /
0145      4 5X, ' ENERGY FLOW OUT OF N.Z. ----', 1P1G11.4, ' J/SEC ' /
0146      5 5X, ' CONVECTION ENERGY OUT OF R.Z. -----', 1P1G11.4, ' J/SEC ' /
0147      6 5X, ' CONVECTION ENERGY OUT OF N.Z. -----', 1P1G11.4, ' J/SEC ' /
0148      7 5X/5X, ' FINAL ENERGY OF R.Z. -----', 1P1G11.4, ' J ' /
0149      8 5X, ' FINAL ENERGY OF N.Z. -----', 1P1G11.4, ' J ' /
0150      9 5X/5X, ' INITIAL ENERGY OF R.Z. -----', 1P1G11.4, ' J ' /
0151      1 5X, ' INITIAL ENERGY OF N.Z. -----', 1P1G11.4, ' J ' /
0152      2 5X/5X, ' SUM OF ENERGY CHANGE TOTAL -', 1P1G11.4, ' J ' /
0153      3 5X, ' TOTAL INTERNAL ENERGY -----', 1P1G11.4, ' J ' )
0154
0155      C
0156      C 10      CONTINUE
0157
0158      C      That's all folks!
0159      RETURN
0160      END

```

PROGRAM SECTIONS

Name	Bytes	Attributes
0 \$CODE	1012	PIC CON REL LCL SHR EXE RD NOWRT LONG
1 \$PDATA	1827	SHR NOEXE RD NOWRT LONG
2 \$LOCAL	32	SHR NOEXE RD WRT QUAD
3 OUT	12	NOSHR NOEXE RD WRT LONG
4 INPUT	84	SHR NOEXE RD WRT LONG
5 PROP	64	SHR NOEXE RD WRT LONG
Total Space Allocated	3031	

ENTRY POINTS

Address	Type	Name
0-00000000	OUTPUT	

VARIABLES

Address	Type	Name	Address	Type	Name	Address	Type	Name
5-00000038	R*8	APLI	2-00000018	R*8	APPB	4-00000008	R*8	APRV
5-00000010	R*8	DLI	5-00000008	R*8	DLIOH	5-00000000	R*8	DLMB
AP-0000005C@	R*8	DRDT	AP-00000048@	R*8	ENGIN	AP-00000044@	R*8	ENGOUT
3-00000000	I*4	JOUT1	3-00000004	I*4	JOUT2	3-00000008	I*4	JOUT3
2-00000000	R*8	MH20	AP-0000001C@	R*8	MH20FR	AP-00000038@	R*8	MLIOHF
AP-0000002C@	R*8	MPBF	AP-00000024@	R*8	MPRVFR	AP-00000074@	I*4	NFLAG
4-00000030	I*4	NPIPES	4-00000044	R*8	PEPS	AP-00000010@	R*8	PF
4-00000010	R*8	PPRV	AP-00000040@	R*8	PVDOT	AP-0000003C@	R*8	QCOND
AP-00000054@	R*8	QFCRZ	AP-00000060@	R*8	SUMQ	AP-00000064@	R*8	SUMU
5-00000030	R*8	TDLMB	AP-0000000C@	R*8	TEMPNF	AP-00000008@	R*8	TEMPRF
AP-00000004@	R*8	TIME	4-00000028	R*8	TIMEND	AP-0000007C@	R*8	TMAX
AP-00000030@	R*8	UMLIF	AP-00000050@	R*8	UNZF	AP-0000006C@	R*8	UNZI
AP-00000068@	R*8	URZI	AP-00000018@	R*8	VGASF	4-0000004C	R*8	VR0
4-00000034	R*8	VTOT	4-00000000	R*8	X	2-00000010	R*8	XAPLI
5-00000020	R*8	XLMBHF						

LABELS

Address	Label	Address	Label	Address	Label	Address	Label
0-0000003F3	10	1-000000000	100'	1-000000016	101'	1-000000025	102'
1-000000227	201'	1-000000316	202'	1-0000004E3	203'	1-00000004A	220'
						1-000000034	103'
						1-0000001BA	200'

18-Jul-1984 00:20:42 VAX-11 FORTRAN V3.5-62
 18-Jul-1984 00:19:51 DUAT:[NUKE.JIM]MARSPRG.;26

OUTPUT

COMMAND QUALIFIERS

```

FORTRAN /LIST MARSPRG.;26

/CHECK=(NOBOUNDS,OVERFLOW,NOUNDERFLOW)
/DEBUG=(NOSYMBOLS,TRACEBACK)
/STANDARD=(NOSYNTAX,NOSOURCE_FORM)
/SHOW=(NOPREPROCESSOR,NOINCLUDE,MAP)
/F77 /NOG_FLOATING /I4 /OPTIMIZE /WARNINGS /NOD_LINES /NOCROSS_REFERENCE /NOMACHINE_CODE /CONTINUATIONS=19
    
```

COMPILATION STATISTICS

```

Run Time:      20.81 seconds
Elapsed Time:   87.85 seconds
Page Faults:    1039
Dynamic Memory: 143 pages
    
```

EOF	54 PAGES COST	\$5.40	PROJ BALANCE	\$996.10	USER BALANCE	\$905.77
-----------	---------------	--------	--------------	----------	--------------	----------

NOMENCLATURE

A	an area
A_b	the area of the steam tube break
A_{prv}	the area of the pressure relief valve and a variable in dynamic model equations
A_t	the surface area of a steam tube
C_1	the factor that determines the probability that the outer tube, of the duplex tube, will fail
C_2	the factor that determines the probability that the inner tube will fail due to the failure of the outer tube
C_3	the factor that determines the probability that the outer tube will fail, due to the failure of the inner tube
C_4	the factor that determines the probability that a small break will deteriorate into a large break
C_H	the molar specific heat of hydrogen
C_L	the molar specific heat of lithium
C_{LH}	the molar specific heat of lithium hydroxide
E_R	the total internal energy of the reaction zone
E_{tot}	the overall unavailability of a steam generator design
h	the overall heat transfer coefficient of the steam tube
i_b	enthalpy of the liquid metal breeder entering the reaction zone
i_f	the heat of formation of the liquid metal breeder, $Li_{17}Pb_{83}$
i_{wb}	the enthalpy of the water/steam flowing through the steam tube break
i_{wf}	the final enthalpy of the water in the Thermodynamic Equilibrium Model
i_{wo}	the initial enthalpy of the water in the Thermodynamic Equilibrium Model

k_n	the thermal conductivity of the nonreaction zone, liquid metal breeder
\dot{m}_{bp}	the molar flow rate of unreacted liquid metal breeder through the pressure relief valve
\dot{m}_{br}	the molar flow rate of liquid metal breeder into the reaction zone
\dot{m}_w	the molar flow rate of water into the reaction zone
m_n	the total mass of the nonreaction zone
m_R	the total mass of the reaction zone
N_H	the number of moles of hydrogen
P	the variable system pressure
P_ℓ	the final quasi-steady pressure
P_{max}	the maximum system pressure
P_∞	the pressure relief valve back pressure, assumed to be 1 atm
Q	the heat of reaction
Q_C	The conduction heat flow between the reaction zone and nonreaction zone
Q_n	the convective heat flow from the nonreaction zone to unbroken steam tubes
Q_r	the convective heat flow from the reaction zone to unbroken steam tubes
R	the radius of the reaction zone
S_{wb}	the entropy of the water at the tube break
S_{N0}	the initial entropy of the water
T_f	the final thermodynamic equilibrium temperature
T_n	the average temperature of the nonreaction zone
T_{ni}	the initial temperature of the nonreaction zone
T_0	the reference temperature in the Thermodynamic Equilibrium Model, chosen to be 0°C
T_r	the average temperature of the reaction zone
T_w	the average temperature of the water/steam in the steam tubes, assumed to be 648°K

V_r	the volume of the reaction zone
v_{wb}	the velocity of the water flowing through the steam tube break
x	the mixing parameter. In the Thermodynamic Equilibrium Model it is defined as the molar ratio of water to Li in the initial mixture. In the Dynamic Model, it is defined as the ratio of the molar flow rate of H_2O to the molar flow rate of Li into the reaction zone per timestep.
α_n	the thermal diffusivity of the liquid metal breeder
ΔG	the Gibb's free energy of the $Li_{17}Pb_{83}$
ΔS	the entropy of the $Li_{17}Pb_{83}$
Δt	the length of the timestep is seconds
λ	the probability of a specific accident scenario
λ_i	the probability that the inner tube, of the duplex tube, will fail
λ_o	the probability that the outer tube will fail
λ_{PWR}	the probability that a PWR steam tube will fail
λ_{SG}	the overall probability that a forced shutdown of the steam generator will occur
μ	the reciprocal of the time needed to repair the steam generator, which has been shut down due to a specific accident scenario
λ	the conduction length scale derived from boundary layer theory
ρ_b	the density of the liquid metal breeder
ρ_{wb}	the density of the water/steam flowing through the steam tube break

References

1. P.J. Krane, M.S. Kazimi, "An Evaluation of Accidental Water Reactions with Lithium Compounds in Fusion Reactor Blankets," Plasma Fusion Center and Department of Nuc. Engr., MIT (July 1981).
2. S.J. Piet et al., "Potential Consequences of Tokamak Fusion Reactor Accidents: The Materials Impact," Plasma Fusion Center, MIT (June 1982).
3. R.G. Clemmer, D.R. Armstrong, et al., "An Experimental Study of the Reaction of $\text{Li}_{17}\text{Pb}_2$ with Water," Trans. Am. Nucl. Soc. 32, 71 (1979).
4. R.G. Clemmer, D.R. Armstrong, et al., "The Reactions of Li-Pb Alloys with Water," Trans. Am. Nucl. Soc. 34, 55 (1980).
5. A.G. Rogers, B.L. Benedict, et al., "Liquid Li-Pb-Bi, A New Tritium Breeder," Eng. Fusion Research Proc., Chicago, October 1981.
6. L. Muhlestein, Private Communication (October 1982).
7. D.W. Jepson et al., "Fusion Reactor Blanket Material Safety Compatability Studies," Nuclear Tech. 20, 450 (August 1983).
8. J.L. Rouyer, "Safety Analysis," Commissariat a l'Energie Atomique, ARD 1-044-E1 (April 1983).
9. H. Klippel, "Safety Analysis of a $\text{Li}_{17}\text{Pb}_{83}$ Liquid Breeder Blanket," Ener. Centrum Nederland, FYS-FUS-82-6 (June 1982).
10. B.G. Logan et al., "Mirror Advanced Reactor Study Interim Design Report," UCRL-53333 (April 1983).
11. M. Corradini, G. Moses, "A Dynamic Model for Fuel-Coolant Mixing," ANS Int'l. Mtg., on LWR Severe Accident Evaluation, Boston (August 1983).
12. M. Berman, LWR Safety Semi-Annual Report, Sandia National Laboratories, SAND-82-15721, Chapter 2 (June 1983).
13. M. Corradini, "A Proposed Model for Fuel-Coolant Mixing," ANS Int'l. Thermal Reactor Safety Mtg., Chicago (August 1982).
14. L. Efferding, Private Communication, Westinghouse Corp. (Nov. 1982).
15. E.M. Larsen, Private Communication (December 1982).
16. M.L. Corradini, "Phenomenological Modeling of the Triggering Phase of Small-Scale Steam Explosion Experiments," Nucl. Sci. and Eng. 78, 1540170 (1981).
17. R. Bird et al., Transport Phenomena, Wiley & Sons, NY (1960).

18. L. Baker et al., "Studies of Metal-Water Reactions at High Temperatures," ANL-6548, Argonne National Lab (May 1982).
19. M. Corradini et al., "Modeling Lithium-Lead/Water Interactions," 5th Int'l. Topical Mtg. on Fusion Energy, Knoxville, TN (April 1983).
20. D.M. France et al., "Blowdown Tests in a Sodium Heated Steam Generator," ANS Transaction V45, Detroit (June 1983).
21. "IEEE Guide for General Principles of Reliability Analysis of Nuclear Power Generating Station Protection System," IEEE Std 352-1975.