






# Overview of ARIES-CS In-vessel Components: Integration of Nuclear, Economics, and Safety Constraints in Compact Stellarator Design

**L. El-Guebaly**  
and the ARIES Team

**Fusion Technology Institute**  
University of Wisconsin - Madison  
<http://fti.neep.wisc.edu/UWNeutronicsCenterOfExcellence>

2<sup>nd</sup> IAEA TM on  
First Generation of Fusion Power Plants: Design & Technology  
June 20 - 22, 2007  
Vienna, Austria


# Multi-Institution ARIES Project




ARIES-CS



ARIES-AT



ARIES-ST



ARIES-I



ARIES-III



2

ARIES-IV




SPPS









ARIES-RS



# Six Stellarator Power Plants Developed Worldwide Over Past 25 y



# Six Stellarator Power Plants Developed Worldwide Over Past 25 y (Cont.)





# Stellarators Offer Unique Features and Engineering Challenges

---

## Advantages:

- Inherently steady-state devices
- No need for large plasma current
- No external current drive
- No risk of plasma disruptions
- Low recirculating power due to absence of current-drive requirements
- No instability and positional control systems.

## Challenges:

- Complex geometry
- Maintainability and component replacement
- Highly constrained local shielding areas
- 3-D modeling
- Managing large volume of active materials.





# ARIES Compact Stellarator

## Study aimed at reducing stellarators' size by:

- Developing compact configuration with advanced physics & technology
- Optimizing minimum plasma-coil distance ( $\Delta_{\min}$ ) through rigorous nuclear assessment.

## 3 Field Periods Configuration

Average Major Radius	7.75 m
Average Minor Radius	1.7 m
Aspect Ratio	4.5
Fusion Power	2400 MW
Average NWL	2.6 MW/m <sup>2</sup>
Net Electric Power	1000 MW <sub>e</sub>
COE (\$2004)	78 mills/kWh



# ARIES-CS Nuclear Areas of Research

## Radial Build Definition:

- Dimension of all components
- Optimal composition

## Neutron Wall Loading Profile:

- Toroidal & poloidal distribution
- Peak & average values

## Blanket Parameters:

- Dimension
- TBR, enrichment,  $M_n$
- Nuclear heat load
- Damage to FW
- Service lifetime


## High-Performance Shielding Module at $\Delta_{\min}$

## Activation Issues:


- Activity and decay heat
- Thermal response during LOCA/LOFA events
- Radwaste classification & management

## Radiation Protection:

- Shield dimension & optimal composition
- Damage profile at shield, manifolds, VV, and magnets
- Streaming issues
- Workers and public protection



# Nuclear Task Involves Active Interaction with many Disciplines







# Reference Dual-cooled LiPb/FS Blanket Selected with Advanced LiPb/SiC as Backup

<u>Breeder</u>	<u>Multiplier</u>	<u>Structure</u>	<u>FW/Blanket Coolant</u>	<u>Shield Coolant</u>	<u>VV Coolant</u>
----------------	-------------------	------------------	-------------------------------	---------------------------	-----------------------

## Internal VV\*:

Flibe	Be	FS	Flibe	Flibe	H <sub>2</sub> O
LiPb (backup)	—	SiC	LiPb	LiPb	H <sub>2</sub> O

LiPb (reference)	—	FS	He/LiPb	He	H <sub>2</sub> O
------------------	---	----	---------	----	------------------

Li <sub>4</sub> SiO <sub>4</sub>	Be	FS	He	He	H <sub>2</sub> O
----------------------------------	----	----	----	----	------------------

## **External VV#:**

LiPb	—	FS	He/LiPb	He or H <sub>2</sub> O	He
------	---	----	---------	------------------------	----

Li	—	FS	He/Li	He	He
----	---	----	-------	----	----

\* VV inside magnets.

# VV outside magnets.





# ARIES-CS Requirements Guide

## In-vessel Component Design


---

<b>Calculated Overall TBR</b>	1.1	
<b>Net TBR</b> (for T self-sufficiency)	~1.01	
<b>Damage to Structure</b> (for structural integrity)	200	dpa - advanced FS
<b>Helium Production @ Manifolds and VV</b> (for reweldability of FS)	1	He appm
<b>S/C Magnet (@ 4 K):</b>		
Peak Fast n <b>fluence</b> to Nb <sub>3</sub> Sn ( $E_n > 0.1$ MeV)	$10^{19}$	n/cm <sup>2</sup>
Peak Nuclear <b>heating</b>	2	mW/cm <sup>3</sup>
Peak <b>dpa</b> to Cu stabilizer	$6 \times 10^{-3}$	dpa
Peak <b>Dose</b> to electric insulator	$< 10^{11}$	rads
<b>Plant Lifetime</b>	40	FPY
<b>Availability</b>	85%	
<b>Operational dose to workers and public</b>	$< 2.5$	mrem/h


# FW Shape Varies Toroidally and Poloidally: Challenging 3-D Modeling Problem





# UW Developed CAD/MCNP Coupling Approach to Model ARIES-CS for Nuclear Assessment



- Only viable approach for ARIES-CS 3-D neutronics modeling.
- Geometry and ray tracing in CAD
- Radiation transport physics in MCNPX.




# Neutron Wall Loading Distribution



	Peak (Min) [MW/m²]	Toroidal Angle (degrees)	Poloidal Angle (degrees)
	5.26 (0.32)	-11 (-4)	-18 (-116)



Peak/Ave. NWL = 2






# Well-Optimized Blanket & Shield Protect Vital Components



(5.3 MW/m<sup>2</sup> Peak  $\Gamma$ )



# High Performance Components at $\Delta_{\min}$ Help Achieve Compactness, Minimize Major Radius, and Enhance Economics



# Tritium Breeding Requirement Determined Minimum Major Radius




- Large machines breed more T as non-uniform blanket coverage decreases with R.
- Designs with  $R < 7.5$  m will not provide T self-sufficiency.

# R=7.75 m Reference Design Provides Tritium Self-Sufficiency

**3-D model** includes essential components for TBR:

- Non-uniform and full blanket/shield
- Homogenized: FW/Blanket/BW  
Shield  
Manifolds  
Divertor.

**Calculated Overall TBR = 1.1**  
with 70% Li enrichment






# Neutron Streaming Through Penetrations Compromises Shielding Performance

- **7 types of penetrations:**

- 198 He tubes for blanket (32 cm ID)
- **24 Divertor He access pipes (30-60 cm ID)**
- 30 Divertor pumping ducts (42 x 120 cm each)
- 12 Large pumping ducts (1 x 1.25 m each)
- 3 ECH ducts (24 x 54 cm each).
- 6 main He pipes - HX to/from blanket (72 cm ID each)
- 6 main He pipes - HX to/from divertor (70 cm ID each)


- **Potential solutions:**

- Local shield behind penetrations
- He tube axis oriented toward lower neutron source
- Penetration shield surrounding ducts
- Replaceable shield close to penetrations
- Avoid rewelding VV and manifolds close to penetrations
- Bends included in some penetrations.







# 3-D Assessment of Streaming Through Divertor He Access Pipe



Attila 3-D  
Model



Shield inserts help protect surrounding components




# Key Nuclear Parameters

---

<b>Peak NWL</b>	<b>5.3 MW/m<sup>2</sup></b>
<b>Average NWL</b>	<b>2.6 MW/m<sup>2</sup></b>
<b>Peak to Average NWL</b>	<b>2</b>
<b>Calculated Overall TBR</b>	<b>1.1</b> with 70% Li enrichment
<b>Net TBR</b>	<b>~1.01</b>
<b>FW/blanket Lifetime</b>	<b>3 FPY</b>
<b>Shield/manifold/VV/magnet Lifetime</b>	<b>40 FPY</b>
<b>Overall Energy Multiplication</b>	<b>1.16</b>
$\Delta_{\min}$	<b>1.3 m</b>
$\Delta_{\max}$	<b>1.8 m</b>


# ARIES-CS Major Radius

## Approaches R of Advanced Tokamaks



Well optimized radial build along with advanced physics and technologies helped reduce ARIES-CS size

# ARIES Project Committed to Radwaste Minimization



Stellarator waste volume dropped by 3-fold  
over 25 y study period

\* Actual volumes (not compacted, no replacements).



# Highlights of ARIES-CS Safety Features

---

## Environmental impact:

- **Low activation materials** with strict impurity control  
⇒ minimal long-term environmental impact.
- **No high-level waste.**
- **Minimal radioactive releases<sup>#</sup>** during normal and abnormal operations.

## No energy and pressurization threats to confinement barriers (VV and cryostat):

- Decay heat problem solved by design
- Chemical reaction avoided
- No combustible gas generated
- Chemical energy controlled by design
- Overpressure protection system
- Rapid, benign plasma shutdown.

## Occupational and public safety:

- **No evacuation plan** following abnormal events (early dose at site boundary  $< 1 \text{ rem}^*$ ) to avoid disturbing public daily life.
- **Low dose** to workers and personnel during operation and maintenance activity ( $< 2.5 \text{ mrem/h}^*$ ).
- **Public safety** during normal operation (bio-dose  $\ll 2.5 \text{ mrem/h}^*$ ) and following credible accidents:
  - External events (seismic, hurricanes, tornadoes, etc.).
  - LOCA, LOFA, LOVA, and by-pass events.



---

<sup>#</sup> Such as T, volatile activated structure, corrosion products, and erosion dust. Or, from liquid and gas leaks.

<sup>\*</sup> 1 rem (= 10 m Sv) accident dose stated in Fusion Safety Standards, DOE report, DOE-STD-6002-96 (1996).



# In-vessel Components Exhibit Structural Integrity during LOCA/LOFA Event



- **Design Base Accident scenario:** He LOCA and LiPb LOFA in **all** modules and water LOFA in VV.
- Plasma stays on for 3 seconds after onset of LOCA/LOFA.
- **Peak FW temperature remains below 740°C** – reusability limit for ferritic steel.

# Radwaste Management Approach

---

- **Three options examined:**
  - **Disposal** in repositories: LLW ( $WDR < 1$ )
  - **Recycling** – reuse within nuclear facilities ( $dose < 10,000 \text{ Sv/h}$ )
  - **Clearance** – release slightly-radioactive materials to commercial market if  $CI < 1$ .
- Lack of geological repositories and tighter environmental controls will force fusion designers to **promote recycling and clearance, avoiding disposal\***  
⇒ **minimize radwaste burden for future generations.**
- There's **growing international effort** in support of this new trend.

---

\* L. El-Guebaly, "Environmental Aspects of Recent Trend in Managing Fusion Radwaste: Recycling and Clearance, Avoiding Disposal," This IAEA TM, Wednesday @ 9 AM.



# Comparison Between Reference and Backup Systems

	LiPb/He/FS	LiPb/SiC
Calculated Overall <b>TBR</b>	1.1	1.1
FW/blanket <b>lifetime</b>	3 FPY	3.4 FPY
Overall <b>energy multiplication</b>	1.16	1.1
$\eta_{th}$	42%	56%
Structure <b>unit cost</b> *	103 \$/kg	510 \$/kg
Blanket/divertor/shield/manifolds <b>cost</b> *	\$288M	\$282M
Cost* of <b>heat transfer/transport system</b>	\$475M	\$175M
<b>Pumping power</b>	183 MW <sub>e</sub>	---
<b>LSA factor</b>	2	1
<b>Cost of Electricity</b> *: Reference design (R=7.75 m)	<b>78</b> mills/kWh	<b>60</b> mills/kWh
Full blanket/shield everywhere (R=10.1 m)	<b>87</b> mills/kWh	

\* in 2004 \$.



# Conclusions

---

- **Nuclear assessment** received considerable attention during ARIES-CS design process.
- **First time ever** complex stellarator geometry modeled for nuclear assessment using UW newly developed **CAD/MCNP coupling approach**.
- **Radial build** satisfies design requirements in terms of breeding sufficient tritium and shielding vital components.
- **Novel shielding approach** developed for ARIES-CS helped reduce radial standoff by 40%, major radius by 30%, and overall cost by 10%.
- ARIES-CS demonstrates **adequate performance in several safety and environmental areas**.
- Successful integration of **well-optimized radial build** into final design, along with carefully selected **engineering parameters** and overarching **safety and environmental constraints**, delivered attractive and **truly compact stellarator power plant**.